



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

## BACnet Testing Laboratories Product Listing

*BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.*

### Listing Information (BTL-31506)

Vendor		Listing Status
Siemens Theilerstrasse 1a 6300 Zug Switzerland		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of December 2024	Revision 18	February 2026

Product Name	Model Numbers	Firmware version
Desigo PXC3 and DXR2 Automation Stations	PXC3.E72-100A, PXC3.E72A-200A, PXC3.E75-100A, PXC3.E75A-200A, PXC3.E72A-100A, PXC3.E16A-200A,  DXR2.E09-101A, DXR2.E09-101A/BP, DXR2.E09-101A/TB, DXR2.E09T-101A, DXR2.E09T-101A/BP, DXR2.E10-101A, DXR2.E10-101A/BP, DXR2.E10PL-102B, DXR2.E10PLX-102B, DXR2.E12P-102A, DXR2.E12P-102A/BP, DXR2.E12P-102B, DXR2.E12P-102K, DXR2.E12PX-102B, DXR2.E12PX-102K, DXR2.T12P-102B, DXR2.E18-101A, DXR2.E18-101A/BP,	01.22.273.16

	DXR2.E18-101B, DXR2.E18-101K, DXP2.E18-110BR, DXP2.M18-110BR,  DXR2.M09-101A, DXR2.M09T-101A, DXR2.M10-101A, DXR2.M10PL-102B, DXR2.M10PLX-102B, DXR2.M11-101A, DXR2.M11-101B, DXR2.M11-101K, DXR2.M12P-102A, DXR2.M12P-102B, DXR2.M12P-102K, DXR2.M12PX-102B, DXR2.M12PX-102K, DXR2.M18-101A, DXR2.M18-101B, DXR2.M18-101K, DXR2.T18-101B,  DXR2.E17C-103A, DXR2.E17C-103B, DXR2.E17CX-103A, DXR2.E17CX-103B, DXR2.M17C-103B, DXR2.M17CX-103B	
--	---	--

## Device Profiles

Profile	Model Numbers
BACnet Advanced Application Controller (B-AAC)	All models

## BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-A	DS-COV-A
	Change Of Value-B	DS-COV-B
	Change Of Value Unsubscribed-B	DS-COVU-B

Alarm and Event Notification	Notification-A	AE-N-A
	Notification Internal-B	AE-N-I-B
	Acknowledge-B	AE-ACK-B
	Information-B	AE-INFO-B
	Event Log-Internal-B	AE-EL-I-B
	Configurable Recipient Lists-B	AE-CRL-B

Scheduling	Internal-B	SCHED-I-B
Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Automated Trend Retrieval-B	T-ATR-B
Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B
Foreign Device Registration-A	NM-FDR-A	

## Object Type Support

Alert Enrollment	Analog Input	Analog Output
Analog Value	Binary Input	Binary Output
Binary Value	Calendar	Command
Device	Event Enrollment	Event Log
File	Loop	Multi-State Input
Multi-State Output	Multi-State Value	Network Port
Notification Class	Positive Integer Value	Program
Schedule	Structured View	Trend Log

## Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device BACnet/IP, 'DIX' Ethernet
MS/TP Manager	9600, 19200, 38400, 76800, 115200
BACnet/SC	

## Character Set Support

ISO 10646 (UTF-8)
IBM/Microsoft DBCS
JIS X 0208
ISO 10646 (UCS-4)
ISO 10646 (UCS-2)
ISO 8859-1