



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-31145)

Vendor		Listing Status
SungHan. Co., Ltd. & Laboratory 2F, Hosan Building, 71, Daehak-ro 76beon-gil Yuseong-gu, Daejeon Republic of Korea		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of January 2020	Revision 14 (135-2012)	July 2021

Product Name	Model Numbers	Firmware version
SmartBEN-BMI-BAC	SmartBEN-BMI-BAC-OWS	4.10.1.36.2

Device Profiles

Profile	Model Numbers
BACnet Operator Workstation (B-OWS)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-A	DS-COV-A
	Change Of Value-B	DS-COV-B
	Change Of Value Property-B	DS-COVP-B
	View-A	DS-V-A
	Advanced View-A	DS-AV-A
	Modify-A	DS-M-A
Advanced Modify-A	DS-AM-A	

Alarm and Event Notification	Notification-A	AE-N-A
	Notification Internal-B	AE-N-I-B
	Acknowledge-A	AE-ACK-A
	Acknowledge-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information-A	AE-INFO-A
	Information-B	AE-INFO-B
	View Notifications-A	AE-VN-A
	Advanced View Notifications-A	AE-AVN-A
	View and Modify-A	AE-VM-A
	Advanced View and Modify-A	AE-AVM-A
	Alarm Summary View-A	AE-AS-A
	Event Log View-A	AE-ELV-A
Event Log View and Modify-A	AE-ELVM-A	

Scheduling	Advanced View and Modify-A	SCHED-AVM-A
	View and Modify-A	SCHED-VM-A
	Weekly Schedule-A	SCHED-WS-A

Trending	Viewing and Modifying Trends-A	T-VMT-A
	Automated Trend Retrieval-A	T-ATR-A
	Viewing and Modifying Multiple Values-A	T-VMMV-A
	Automated Multiple Value Retrieval-A	T-AMVR-A
	View-A	T-V-A
	Advanced View and Modify-A	T-AVM-A
	Archival-A	T-A-A

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-A	DM-DCC-A
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-A	DM-TS-A
	UTCTimeSynchronization-A	DM-UTC-A
	ReinitializeDevice-A	DM-RD-A
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-A	DM-BR-A
	Backup and Restore-B	DM-BR-B
	Restart-B	DM-R-B
	List Manipulation-A	DM-LM-A
	List Manipulation-B	DM-LM-B
	Object Creation and Deletion-A	DM-OCD-A
	Automatic Network Mapping-A	DM-ANM-A
	Automatic Device Mapping-A	DM-ADM-A
	Automatic Time Synchronization-A	DM-ATS-A
	Manual Time Synchronization-A	DM-MTS-A
Router Configuration-B	NM-RC-B	

Object Type Support

Analog Output	Binary Output	Device
File	Integer Value	Notification Class

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD Register as Foreign Device BACnet/IP, 'DIX' Ethernet
Ethernet	ISO 8802-3, 10BASET

Character Set Support

ISO 10646 (UTF-8)
IBM/Microsoft DBCS
JIS X 0208
ISO 8859-1
ISO 10646 (UCS-4)