



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-24328-1)

Vendor		Listing Status
SungHan. Co., Ltd. & Laboratory 2nd Floor Hosan Building 495-4, Gung-dong, Yuseong-gu, Daejeon, 305-335 Republic of Korea		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of July 2009	Revision 7 (135-2008)	July 2011

Product Name	Model Number(s)	Software Version
BEN-MMI-Management-OWS	SmartBEN-BMI-OWS	BM-OWS1.0

Device Profiles

Profile	Model Numbers
BACnet Operator Workstation (B-OWS)	SmartBEN-BMI-OWS

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	View-A	DS-V-A
Modify-A	DS-M-A	

Alarm and Event Management	Alarm and Event-Notification-A	AE-N-A
	Alarm and Event-ACK-A	AE-ACK-A
	Alarm and Event-View Notifications-A	AE-VN-A
	Alarm and Event-Advanced View Notifications-A	AE-AVN-A
	Alarm and Event-View and Modify-A	AE-VM-A
	Alarm and Event-Alarm Summary View-A	AE-AS-A
	Alarm and Event-Information-A	AE-INFO-A

Scheduling	Scheduling-View and Modify-A	SCHED-VM-A
------------	------------------------------	------------

Trending	Trending-View-A	T-V-A
	Trending-Automated Trend Retrieval-A	T-ATR-A

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	ReinitializeDevice-B	DM-RD-B
	Automatic Device Mapping-A	DM-ADM-A
	Automatic Network Mapping-A	DM-ANM-A
	Automatic Time Synchronization-A	DM-ATS-A
	Manual Time Synchronization-A	DM-MTS-A
	Time Synchronization-A	DM-TS-A
	Time Synchronization-B	DM-TS-B
	UTC Time Synchronization-A	DM-UTC-A
	UTC TimeSynchronization-B	DM-UTC-B
	List Manipulation-A	DM-LM-A
List Manipulation-B	DM-LM-B	

Object Type Support

Device		
--------	--	--

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD
Ethernet	

Networking Options

Networking Functionality	Media
Router	BACnet/IP (Annex J) – Ethernet

Character Set Support

ANSI X3.4 ISO 10646 (UCS-2)
