



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information (BTL-30116)

Vendor Swegon AB Frejgatan 14 535 23 Kvänum Sweden		Listing Status Listed Product
Test Requirements Requirements as of August 2012	BACnet Protocol Revision Revision 6	Date Tested June 2013

Product Name GOLD IQnomic	Model Number Version C, D	Software Version GOLD PV 6.10, BACnet version: 1.2
------------------------------	------------------------------	--

Device Profiles

Profile BACnet Application Specific Controller (B-ASC)	Model Numbers All models
---	-----------------------------

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-B	DS-COV-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	ACK-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information B	AE-INFO-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	ReinitializeDevice-B	DM-RD-B
	ListManipulation-B	DM-LM-B

Object Type Support

Analog Input	Analog Value	Device
Binary Input	Binary Value	Notification Class

Data Link Layer Options

Media	Options
BACnet/IP	BBMD

Character Set Support

ANSI X3.4 ISO 8859-1
