



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BACnet International website.

Listing Information (BTL-30521)

Vendor		Listing Status
SysCom Automationstechnik GmbH An der Lehmkaute 13 56470 Bad Marienberg Germany		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of October 2018	Revision 15	November 2019

Product Name	Model Numbers	Firmware version
SB-BACnet	SB-BACnet	2.0.0.0

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-A	DS-COV-A
	Change Of Value-B	DS-COV-B
	Change Of Value Property-A	DS-COVP-A
	Change Of Value Property-B	DS-COVP-B
	Change Of Value Unsubscribed-A	DS-COVU-A
	Change Of Value Unsubscribed-B	DS-COVU-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	Notification External-B	AE-N-E-B
	Acknowledge-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B
	Event Log-Internal-B	AE-EL-I-B
	Event Log-External-B	AE-EL-E-B

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Viewing and Modifying Trends External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-A	DM-TS-A
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-A	DM-UTC-A
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Restart-A	DM-R-A
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B
	Object Creation and Deletion-B	DM-OCD-B
	Automatic Network Mapping-A	DM-ANM-A
	Automatic Time Synchronization-A	DM-ATS-A
	Slave Proxy-B	DM-SP-B

Network Management	Router Configuration-B	NM-RC-B
--------------------	------------------------	---------

Object Type Support

Accumulator	Analog Input	Analog Output
Analog Value	Binary Input	Binary Output
Binary Value	Calendar	Command
Device	Event Enrollment	Event Log
File	Integer Value	Large Analog Value
Loop	Multi-State Input	Multi-State Output
Multi-State Value	Notification Class	Positive Integer Value
Program	Schedule	Trend Log

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD, Register as Foreign Device
MS/TP Master	9600, 19200, 38400, 57600, 76800, 115200

Networking Options

Networking Functionality	Media
Router	BACnet/IP (Annex J), MS/TP
BBMD	BACnet/IP (Annex J), MS/TP

Character Set Support

ISO 10646 (UTF-8)
ISO 10646 (UCS-2)
ISO 8859-1