



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information (BTL-30086)

Vendor Vaisala Oyj Vanha Nurmijärventie 21 01670 Vantaa Finland		Listing Status Listed Product
Test Requirements Requirements as of December 2011	BACnet Protocol Revision Revision 4	Date Tested February 2014

Product Name XMW90	Model Number(s) HMW90, GMW90, GMW95R	Software Version 1.1.0.0
-----------------------	---	-----------------------------

Device Profiles

Profile BACnet Smart Sensor (B-SS)	Model Numbers All models
---------------------------------------	-----------------------------

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	ReinitializeDevice-B	DM-RD-B

Object Type Support

Analog Input	Analog Value	Device
--------------	--------------	--------

Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 57600, 76800, 115200
MS/TP slave	9600, 19200, 38400, 57600, 76800, 115200

Character Set Support

ANSI X3.4
