



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BACnet International website.

Listing Information (BTL-30442)

| | | |
|---|--------------------------|----------------|
| Vendor | | Listing Status |
| Vaisala Oyj Vanha Nurmijärventie 21 01670 Vantaa Finland | | Listed Product |
| Test Requirements | BACnet Protocol Revision | Date Tested |
| Requirements as of December 2018 | Revision 15 | May 2019 |

| | | |
|--------------|---------------|------------------|
| Product Name | Model Numbers | Firmware version |
| HMD60 | HMD60, HDM65 | 2.0.8 |

Device Profiles

| | |
|--|---------------|
| Profile | Model Numbers |
| BACnet Application Specific Controller (B-ASC) | All models |

BIBBs Supported

| | | |
|--------------|--------------------------------|-----------|
| Data Sharing | ReadProperty-B | DS-RP-B |
| | ReadPropertyMultiple-B | DS-RPM-B |
| | WriteProperty-B | DS-WP-B |
| | Change Of Value Unsubscribed-B | DS-COVU-B |

| | | |
|-------------------|------------------------------|----------|
| Device Management | Dynamic Device Binding-B | DM-DDB-B |
| | Dynamic Object Binding-B | DM-DOB-B |
| | DeviceCommunicationControl-B | DM-DCC-B |
| | ReinitializeDevice-B | DM-RD-B |

Object Type Support

| | | |
|--------------|--------------|--------|
| Analog Input | Analog Value | Device |
|--------------|--------------|--------|

Data Link Layer Options

| Media | Options |
|--------------|--|
| MS/TP Master | 9600, 19200, 38400, 57600, 76800, 115200 |

Character Set Support

| |
|-------------------|
| ISO 10646 (UTF-8) |
|-------------------|