



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BACnet International website.

Listing Information (BTL-25099)

Vendor		Listing Status
Vector Controls GmbH Poststrasse 20. 8620 Wetzikon Switzerland		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 14 (135-2012)	May 2014

Product Name	Model Number(s)	Software Version
CS1-BAC-001	AEX-BAC, AEX2-BAC, TCX2-40863-BAC, TCX2-23343-BAC, TCX2-24273-BAC, TCX2-14050-BAC, TCI2-204.202-BAC, TCI2-204.022-BAC, SDC2-200.101-BAC, SOC2-200.101-BAC, SCC2-200.101- BAC, SDC2-201.102- BAC SOC2-201.102-BAC, SCC- 201.102-BAC, TRI2-221.202	V1.2 R15

Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTC TimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B

Object Type Support

Analog Input	Analog Value	
Binary Value	Device	Multi-state Value

Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 57600, 76800, 115200

Character Set Support

ISO 10646 (UTF-8)
