



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information

| | | |
|---|---|--------------------------------------|
| Vendor Veris Industries 12345 SW Leveton Dr. Tualatin, OR 97062 USA | | Listing Status Listed Product |
| Test Requirements Requirements as of November 2014 | BACnet Protocol Revision Revision 12 | Date Tested October 2015 |

| Product Name | Model Number | Software Version |
|---------------|--------------|------------------|
| Enercept Flex | E23C5 | 1.00.03 |
| Enercept Flex | E23C6 | 1.00.03 |

Device Profiles

| Profile | Model Numbers |
|--|---------------|
| BACnet Application Specific Controller (B-ASC) | All models |

BIBBs Supported

| | | |
|--------------|------------------------|----------|
| Data Sharing | ReadProperty-B | DS-RP-B |
| | ReadPropertyMultiple-B | DS-RPM-B |
| | WriteProperty-B | DS-WP-B |
| | COV-B | DS-COV-B |

| | | |
|-------------------------------|-------------------------------|----------|
| Device and Network Management | Dynamic Device Binding-B | DM-DDB-B |
| | Dynamic Object Binding-B | DM-DOB-B |
| | DeviceCommunicationsControl-B | DM-DCC-B |
| | TimeSynchronization-B | DM-TS-B |
| | ReinitializeDevice-B | DM-RD-B |

Object Type Support

| | | |
|--------------|--------------|--|
| Analog Input | Analog Value | |
| Binary Input | Device | |

Data Link Layer Options

| Media | Options |
|-------|--|
| MS/TP | 9600, 19200, 38400, 57600, 76800, 115200 |

Character Set Support

| |
|-------------------|
| ISO 10646 (UTF-8) |
|-------------------|