



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

## BACnet Testing Laboratories Product Listing

*BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.*

### Listing Information (BTL-31534)

Vendor		Listing Status
WAGO GmbH & Co. KG Hansastraße 27 32423 Minden Germany		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of December 2024	Revision 26	December 2025

Product Name	Model Numbers	Firmware version
Controller PFC200	750-8210, 750-8210/0040-0000, 750-8211, 750-8211/0040-0000, 750-8211/0040-0001, 750-8212, 750-8212/0000-0100, 750-8212/0025-0000, 750-8212/0025-0001, 750-8212/0025-0002, 750-8213, 750-8214, 750-8215, 750-8216, 750-8216/0025-0000, 750-8216/0025-0001, 750-8217, 750-8217/0025-0000	2.3.1

## Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC) BACnet Gateway (B-GW) BACnet Secure Connect Hub (B-SCHUB) BACnet Broadcast Management Device (B-BBMD) BACnet Router (B-RTR)	All models

## BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-A	DS-COV-A
	Change Of Value-B	DS-COV-B
	Change Of Value Property-A	DS-COVP-A
	Change Of Value Property-B	DS-COVP-B
	Change Of Value Unsubscribed-B	DS-COVU-B
Value Source Information-B	DS-VSI-B	

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	Notification External-B	AE-N-E-B
	Acknowledge-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B
	Event Log-Internal-B	AE-EL-I-B
	Configurable Recipient Lists-B	AE-CRL-B

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Viewing and Modifying Trends External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B
	Viewing and Modifying Multiple Values Internal-B	T-VMMV-I-B
	Viewing and Modifying Multiple Values External-B	T-VMMV-E-B
	Automated Multiple Value Retrieval-B	T-AMVR-B

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Restart-A	DM-R-A
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B
	Object Creation and Deletion-B	DM-OCD-B
	Router Configuration-B	NM-RC-B
	BBMD Configuration-B	NM-BBMD-C-B
Secure Connect Hub-B	NM-SCH-B	
Embedded Objects-B	GW-EO-B	

## Object Type Support

Accumulator	Analog Input	Analog Output
Analog Value	Averaging	Binary Input
Binary Output	Binary Value	Bitstring Value
Calendar	Command	Device
Event Enrollment	Event Log	File
Group	Integer Value	Large Analog Value
Loop	Multi-State Input	Multi-State Output
Multi-State Value	Network Port	Notification Class
Program	Pulse Converter	Schedule
Structured View	Trend Log	Trend Log Multiple

## Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD Register as Foreign Device BACnet/IP, 'DIX' Ethernet
BACnet/SC	Hub

## Character Set Support

ISO 10646 (UTF-8)
-------------------