

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.

Listing Information (BTL-30017)

Vendor WindowMaster International A/S Skelstedet 13 2950 Vedbaek Denmark		Listing Status Listed Product
Test Requirements Requirements as of November 2014	BACnet Protocol Revision Revision 10	Date Tested July 2016

Product Name CompactSmoke™ Panel, 10 A	Model Number WSC 310 P	Software Version V1
---	---------------------------	------------------------

Device Profiles

Profile BACnet Smart Actuator (B-SA)	Model Numbers All models
---	-----------------------------

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	COV-B	DS-COV-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Bitstring Value	Device	

Data Link Layer Options

Media	Options
BACnet IP (Annex J)	
MS/TP master	9600, 19200, 38400, 57600, 76800, 115200

Character Set Support

ISO 10646 (UTF-8)
