

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.

Listing Information (BTL-30019)

| | | |
|--|---|--------------------------------------|
| Vendor WindowMaster International A/S Skelstedet 13 2950 Vedbaek Denmark | | Listing Status Listed Product |
| Test Requirements Requirements as of November 2014 | BACnet Protocol Revision Revision 10 | Date Tested July 2016 |

| | | |
|---|---------------------------|------------------------|
| Product Name Comfort MotorController, 10 A | Model Number WCC 310 P | Software Version V1 |
|---|---------------------------|------------------------|

Device Profiles

| | |
|---|-----------------------------|
| Profile BACnet Smart Actuator (B-SA) | Model Numbers All models |
|---|-----------------------------|

BIBBs Supported

| | | |
|--------------|------------------------|----------|
| Data Sharing | ReadProperty-B | DS-RP-B |
| | ReadPropertyMultiple-B | DS-RPM-B |
| | WriteProperty-B | DS-WP-B |
| | COV-B | DS-COV-B |

| | | |
|-------------------------------|--------------------------|----------|
| Device and Network Management | Dynamic Device Binding-B | DM-DDB-B |
| | Dynamic Object Binding-B | DM-DOB-B |

Object Type Support

| | | |
|-----------------|---------------|--------------|
| Analog Input | Analog Output | Analog Value |
| Binary Input | Binary Output | Binary Value |
| Bitstring Value | Device | |

Data Link Layer Options

| Media | Options |
|---------------------|--|
| BACnet IP (Annex J) | |
| MS/TP master | 9600, 19200, 38400, 57600, 76800, 115200 |

Character Set Support

| |
|-------------------|
| ISO 10646 (UTF-8) |
|-------------------|