



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.

Listing Information (BTL-30319)

Vendor		Listing Status
Xylem Service Italy srl via Dottor Vittorio Lombardi 14 Montecchio Maggiore (VICENZA), 36075 Italy		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of October 2016	Revision 12 (135-2010)	May 2018

Product Name	Model Numbers	Software Version
ecocirc XL	130140651M, 130140661M, 130140701M, 130140751N, 130140821N, 130140891A,	654

Device Profiles

Profile	Model Numbers
BACnet Smart Actuator (B-SA)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	WriteProperty-B	DS-WP-B

Device Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B

Object Type Support

Analog Input	Analog Value	Device
--------------	--------------	--------

Data Link Layer Options

Media	Options
MS/TP Master	9600, 19200, 38400, 57600

Character Set Support

ISO 10646 (UTF-8)
