



BACnet® Protocol Implementation Conformance Statement

Vendor		Listing Status
WattMaster Controls, Inc. 8500 NW River Park Drive, Suite 108A Parkville, MO 64152 USA		Listed Product
Test Requirements	BACnet® Protocol Revision	Date Tested
Requirements as of December 2011	Revision 12 (135-2010)	April 2013

Product Name	Model Number	Software Version
DDC Controller	OE377-26B-00001	1.00

BACnet® Standardized Device Profile (Annex L)
BACnet Application Specific Controller (B-ASC)

BIBBs Supported		
Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunication Control-B	DM-DCC-B

Object Type Support		
Device	Analog Input	Analog Value
Binary Input	Binary Value	
Device does not support CreateObject, DeleteObject, and there are no Proprietary Properties.		

Data Link Layer Options	
Media	Options
MS/TP Master	9600,19200, 38400, 57600, 76800

Character Set Support
ANSI X3.4