

# BACnet CONFORMANCE CERTIFICATE



**No. BTL-30584**

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 15.2 and the BTL Testing Policies, see Test Report number VG 2019\_1001544 of MBS.

Product name (B-ASC)
<b>BACnet IP Thermostats/ Transmitters/ Controllers</b>
<b>Model(s)* TxB, HxB, SxB, WxB, VxB, XYB-E, XYB-W</b>
Firmware version
<b>1.52</b>
Vendor
<b>Abies Technology, Inc.</b>
<b>6F., No. 237, Sec. 2, Sichuan Rd, Banqiao Dist. New Taipei City 220, Taiwan (R.O.C)</b>

\* where x is according to listing information

This certificate is valid until **31-Mar-2025**.

**08-May-2020**

Date of Initial Certification

A handwritten signature in blue ink, appearing to read 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann  
Head of Certification Body