
## BACnet CONFORMANCE CERTIFICATE





## No. BTL-30547-1

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 15.2 and the BTL Testing Policies, see Test Report number VG\_2019\_1000570 of MBS.



Product name (B-ASC)

VisualLogic® Unitary Controllers

Model(s) VLC-1188-E, VLC-16160-E, VLC-1600-E, VLC-550-E, VLC-853-E, VLC-651R-E, VLC-660R-E, VAV-SD-E, VAV-SD2A-E, VAV-DD-E, VAV-DD7-E

Firmware version

1.0

Vendor

**Alerton** 

Honeywell International Inc. 1985 Douglas Drive, Dock 1 MS MN10-121B, Golden Valley, MN 55422-4386, USA

This certificate is valid until 31-Mar-2025.

28-Sep-2020

Date of Initial Certification

Dipl.-Ing. G. Weinmann Head of Certification Body

Certification by WSPCert Dr.-Ing. Frank Bitter Kapuzinerweg 7, 70374 Stuttgart, Germany Phone: +49 (0)711 9539220, email: info@wspcert.de

Issued on behalf of BACnet International 1927 Powers Ferry Road, Building 14, Suite 100. Atlanta GA 30339, USA