

BACnet CONFORMANCE CERTIFICATE



No. BTL-31378

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.19. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.3 and the BTL Testing Policies, see Test Report number TC51393 of Protocol Test Lab.

Product name (B-SS)
TotalAlert 360 Controls
Model(s) TA360-S
Firmware version
2.1
Vendor
BeaconMedaes
1059 Paragon Way
Rock Hill, SC 29730, USA

This certificate is valid until **31-Mar-2031**.

29-Jul-2025

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body