

BACnet CONFORMANCE CERTIFICATE



No. BTL-30454

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.12. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 15.1 and the BTL Testing Policies, see Test Report number 18.423.009.001 of iHomeLab.

Product name (B-ASC)
Rotary actuator for butterfly valves
Model(s) PRBUP-MFT-T-x, PKRBUP-MFT-T-x, PRCA-BAC-S2-T-x, PRKCA-BAC-S2-T-x, PRXUP-3-T-x
Software version
03.03.0006
Vendor
Belimo Automation AG Brunnenbachstrasse 1 8340 Hinwil, Switzerland

* where x is according to listing information

This certificate is valid until **31-Mar-2024**

17-Jun-2019

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body