

BACnet CONFORMANCE CERTIFICATE



No. BTL-30305

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.12. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 15.0 and the BTL Testing Policies, see Test Report number 18.859.001.002 of iHomeLab.

Product name (B-ASC)
Field Module for Fire Damper
Model(s) BKN230-24-MOD-BAC
Firmware version
FV 1.0.1
Vendor
BV-Control AG
Russikerstrasse 37
8320 Fehraltorf, Switzerland

This certificate is valid until **31-Mar-2023**.

18-Jun-2018

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body