



Delta Network Sensor: BACstat II

BACNET PROTOCOL IMPLEMENTATION CONFORMANCE STATEMENT

Date: June 15, 2005
Vendor Name: Delta Controls Inc.
Product Name: BACstat II
Product Model Number: DNT-T103, DNT-H103B, DNT-T221, DNT-H121B, DNS-24, DNS-H24B
Product Version: Release 4 Firmware
BACnet Protocol Revision: 4

Product Description

The *Delta BACstat II* is an intelligent room sensor with a custom 3-value LCD display that is running BACnet firmware and may be configured to communicate on Delta's proprietary LINKnet network or directly on a BACnet MS/TP network. When connected to an Application Controller on a LINKnet network it provides programmable remote sensor and expanded I/O capabilities to the controller. When connected on the MS/TP network it functions as an independent BACnet sensor device, with certain models providing optional on-board I/O and built-in application specific control strategies (or algorithms).

BACnet Standardized Device Profile (Annex L):

- BACnet Operator Workstation (B-OWS)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

BACnet Interoperability Building Blocks Supported (Annex K):

BACnet Interoperability Building Block	Supported
Data Sharing	
Data Sharing-ReadProperty-A (DS-RP-A)	<input type="checkbox"/>
Data Sharing-ReadProperty-B (DS-RP-B)	<input checked="" type="checkbox"/>
Data Sharing-ReadPropertyMultiple-A (DS-RPM-A)	<input type="checkbox"/>
Data Sharing-ReadPropertyMultiple-B (DS-RPM-B)	<input checked="" type="checkbox"/>
Data Sharing-ReadPropertyConditional-A (DS-RPC-A)	<input type="checkbox"/>
Data Sharing-ReadPropertyConditional-B (DS-RPC-B)	<input type="checkbox"/>
Data Sharing-WriteProperty-A (DS-WP-A)	<input type="checkbox"/>
Data Sharing-WriteProperty-B (DS-WP-B)	<input checked="" type="checkbox"/>
Data Sharing-WritePropertyMultiple-A (DS-WPM-A)	<input type="checkbox"/>
Data Sharing-WritePropertyMultiple-B (DS-WPM-B)	<input type="checkbox"/>
Data Sharing-COV-A (DS-COV-A)	<input type="checkbox"/>
Data Sharing-COV-B (DS-COV-B)	<input checked="" type="checkbox"/>
Data Sharing-COVP-A (DS-COVP-A)	<input type="checkbox"/>
Data Sharing-COVP-B (DS-COVP-B)	<input type="checkbox"/>
Data Sharing-COV-Unsolicited-A (DS-COVU-A)	<input type="checkbox"/>
Data Sharing-COV-Unsolicited-B (DS-COVU-B)	<input type="checkbox"/>
Scheduling	
Scheduling-A (SCHED-A)	<input type="checkbox"/>
Scheduling-Internal-B (SCHED-I-B)	<input type="checkbox"/>
Scheduling-External-A (SCHED-E-B)	<input type="checkbox"/>
Trending	
Trending-Viewing and Modifying Trends-A (T-VMT-A)	<input type="checkbox"/>
Trending-Viewing and Modifying Trends-Internal-B (T-VMT-I-B)	<input type="checkbox"/>
Trending-Viewing and Modifying Trends-External-B (T-VMT-E-B)	<input type="checkbox"/>
Trending-Automated Trend Retrieval-A (T-ATR-A)	<input type="checkbox"/>
Trending-Automated Trend Retrieval-B (T-ATR-B)	<input type="checkbox"/>
Network Management	
Network Management-Connection Establishment-A (NM-CE-A)	<input type="checkbox"/>
Network Management-Connection Establishment-B (NM-CE-B)	<input type="checkbox"/>
Network Management-Router Configuration-A (NM-RC-A)	<input type="checkbox"/>
Network Management-Router Configuration-B (NM-RC-B)	<input type="checkbox"/>
Alarm and Event Management	
Alarm and Event-Notification-A (AE-N-A)	<input type="checkbox"/>
Alarm and Event-Notification Internal-B (AE-N-I-B)	<input type="checkbox"/>
Alarm and Event-Notification External-A (AE-N-E-B)	<input type="checkbox"/>
Alarm and Event-ACK-A (AE-ACK-A)	<input type="checkbox"/>
Alarm and Event-ACK-B (AE-ACK-B)	<input type="checkbox"/>
Alarm and Event-Alarm Summary-A (AE-ASUM-A)	<input type="checkbox"/>
Alarm and Event-Alarm Summary-B (AE-ASUM-B)	<input type="checkbox"/>
Alarm and Event-Enrollment Summary-A (AE-ESUM-A)	<input type="checkbox"/>
Alarm and Event-Enrollment Summary-B (AE-ESUM-B)	<input type="checkbox"/>
Alarm and Event-Information-A (AE-INFO-A)	<input type="checkbox"/>
Alarm and Event-Information-B (AE-INFO-B)	<input type="checkbox"/>
Alarm and Event-LifeSafety-A (AE-LS-A)	<input type="checkbox"/>
Alarm and Event-LifeSafety-B (AE-LS-B)	<input type="checkbox"/>
Device Management	
Device Management-Dynamic Device Binding-A (DM-DDB-A)	<input type="checkbox"/>
Device Management-Dynamic Device Binding-B (DM-DDB-B)	<input checked="" type="checkbox"/>
Device Management-Dynamic Object Binding-A (DM-DOB-A)	<input type="checkbox"/>
Device Management-Dynamic Object Binding-B (DM-DOB-B)	<input checked="" type="checkbox"/>
Device Management-DeviceCommunicationControl-A (DM-DCC-A)	<input type="checkbox"/>



Delta Network Sensor: BACstat II

BACNET PROTOCOL IMPLEMENTATION CONFORMANCE STATEMENT

BACnet Interoperability Building Block	Supported
Device Management-DeviceCommunicationControl-B (DM-DCC-B)	<input checked="" type="checkbox"/>
Device Management-Private Transfer-A (DM-PT-A)	<input type="checkbox"/>
Device Management-Private Transfer-B (DM-PT-B)	<input type="checkbox"/>
Device Management-Text Message-A (DM-TM-A)	<input type="checkbox"/>
Device Management-Text Message-B (DM-TM-B)	<input type="checkbox"/>
Device Management-TimeSynchronization-A (DM-TS-A)	<input type="checkbox"/>
Device Management-TimeSynchronization-B (DM-TS-B)	<input checked="" type="checkbox"/>
Device Management-UTCTimeSynchronization-A (DM-UTC-A)	<input type="checkbox"/>
Device Management-UTCTimeSynchronization-B (DM-UTC-B)	<input type="checkbox"/>
Device Management-ReinitializeDevice-A (DM-RD-A)	<input type="checkbox"/>
Device Management-ReinitializeDevice-B (DM-RD-B)	<input checked="" type="checkbox"/>
Device Management-Backup and Restore-A (DM-BR-A)	<input type="checkbox"/>
Device Management-Backup and Restore-B (DM-BR-B)	<input type="checkbox"/>
Device Management-List Manipulation-A (DM-LM-A)	<input type="checkbox"/>
Device Management-List Manipulation-B (DM-LM-B)	<input type="checkbox"/>
Device Management-Object Creation and Deletion-A (DM-OCD-A)	<input type="checkbox"/>
Device Management-Object Creation and Deletion-B (DM-OCD-B)	<input type="checkbox"/>
Device Management-Virtual Terminal-A (DM-VT-A)	<input type="checkbox"/>
Device Management-Virtual Terminal-B (DM-VT-B)	<input type="checkbox"/>

Segmentation Capability:

Segmented Requests Supported Window Size: N/A
 Segmented Responses Supported Window Size: N/A

Standard Object Types Supported:

Object-Type	Supported	Dynamically Creatable	Dynamically Deletable	Optional Properties Supported	Writable Properties
Analog Input	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Reliability, COV Increment	Object Name (conditional), COV Increment, Out of Service, Units (conditional), Present Value (conditional), Reliability (conditional)
Analog Value	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	COV Increment	Object Name (conditional), Present Value (conditional), Out of Service, Units (conditional)
Device	YES	N/A	N/A	Max Master, Max Info Frames, Local Time, Local Date	Object Name, Max Master, Max Info Frames

Data Link Layer Options:

- BACnet IP, (Annex J)
- BACnet IP, (Annex J), Foreign Device
- ISO 8802-3, Ethernet (Clause 7) (10Base2, 10Base5, 10BaseT, Fiber)
- ANSI/ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ANSI/ATA 878.1, RS-485 ARCNET (Clause 8), baud rate(s):
- MS/TP master (Clause 9), baud rate(s): 9600, 19200, 38400, 76800
- MS/TP slave (Clause 9), baud rate(s):
- Point-To-Point, EIA 232 (Clause 10), baud rate(s):
- Point-To-Point, modem, (Clause 10), baud rate(s):
- LonTalk, (Clause 11), medium:
- Other:

Device Address Binding:

Is static device binding supported? Yes No
(Necessary for two-way communication with MS/TP slaves and certain other devices.)

Networking Options:

- Router
- Annex H, BACnet Tunnelling
- BACnet/IP Broadcast Management Device (BBMD)
- Does the BBMD support registrations by Foreign Devices?

Character Sets Supported:

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- ANSI X3.4 IBM/Microsoft DBCS JIS C 6226
- ISO 10646 (ICS-4) ISO 10646 (UCS2) ISO 8859-1

If this product is a communication gateway, describe the types of non-BACnet equipment/networks(s) that the gateway supports:

Not applicable.