


BACnet CONFORMANCE CERTIFICATE



No. BTL-30079

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.6. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 9.0 and the BTL Test Policies, see Test Report number TC50335_Delta_DCE_AAC-E of SoftDEL.

| |
|---|
| Product name (B-AAC) |
| Application Controller Models DAC-606E, DAC-633E, DAC-1146E, DAC-1180E, DVC-V304E, DVC-V322E |
| Software version |
| 3.40R1.2 (3.40.189697) |
| Vendor |
| Delta Controls Inc. 17850 56 th Ave Surrey, BC Canada, V3S 1C7 |

This certificate is valid until **07-Jan-2019**.

07-Jan-2014
Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body