

BACnet CONFORMANCE CERTIFICATE



No. BTL-30644

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.16. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 16.1 and the BTL Testing Policies, see Test Report number TC51204 of Protocol Test Lab.

Product name (B-SS)
Powerscout 3HD
Model(s) PS3HD
Software version
2.60b
Vendor
DENT Instruments
925 SW Emkay Dr.
Bend, OR 97702, USA

This certificate is valid until **31-Mar-2026**.

02-Oct-2020

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body