

BACnet Protocol Implementation Conformance Statement

Date: August 8, 2011

Vendor Name: Distech Controls Inc.

Product Name: EC-Net^{AX} Supervisor with OWS Listing

Product Model Number: EC-DR-S-BAC-OWS

Application Software Version: 3.6.35 or higher

Firmware Revision: 3.6.35 or higher

BACnet Protocol Revision: 7

Product Description:

EC-Net^{AX} BACnet OWS Supervisor provides the ability to view, monitor, and control BACnet devices and objects over IP or raw Ethernet, or through a BACnet router to any BACnet media. Devices, points, schedules, alarms, and logs can be learned and managed from EC-Net^{AX}.

BACnet Standardized Device Profile (Annex L):

- BACnet Advanced Operator Workstation (B-AWS)
- BACnet Operator Workstation (B-OWS)
- BACnet Operator Display (B-OD)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

Additional BACnet Interoperability Building Blocks Supported (Annex K):

Data Sharing	Device & Network Management
DS-RP-A, B	DM-DDB-A, B
DS-RPM-A, B	DM-DOB-A, B
DS-WP-A, B	DM-DCC-B
DS-WPM-A,B	DM-RD-B
DS-COV-A	DM-TS-B
DS-V-A	DM-UTC-B
DS-M-A	DM-LM-A, B
	DM-ANM-A
	DM-ADM-A
	DM-ATS-A
	DM-MTS-A

Alarm & Event Management AE-N-A, AE-ACK-A AE-VN-A AE-AVN-A AE-VM-A AE-AS-A	Trending T-ATR-A T-V-A T-A-A
Scheduling SCHED-VM-A	Network Management NM-CE-A

Segmentation Capability:

Feature	Supported	Window size
Transmit Segmented Messages	yes	10
Receive Segmented Messages	yes	any

Standard Object Types Supported:

- The CreateObject and DeleteObject services are not supported, so no objects are dynamically creatable or deletable through BACnet service requests, although these objects are dynamically creatable and deletable through EC-Net^{AX}.
- No general range restrictions exist; however, certain specific applications may have specific range restrictions.
- All potentially available properties are listed for each object type.
- Optional properties are listed in *italics*. Not all instances support all optional properties.
- The Backup and Restore properties from Addendum 135-2008n are included as proprietary properties with proprietary property identifiers. Their behavior is identical to the behavior described in the addendum.
- Writable properties are listed in **bold**. Any range limitations are expressed in parentheses following the property name.

Object Type	Properties
Device	Object_Identifier
	Object_Name
	Object_Type
	System_Status
	Vendor_Name
	Vendor_Identifier
	Model_Name
	Firmware_Revision
	Application_Software_Version
	Location
	Description
	Protocol_Version
	Protocol_Revision
	Protocol_Services_Supported
	Protocol_Object_Types_Supported
	Object_List
	Max_APDU_Length_Accepted
	Segmentation_Supported
	<i>Max_Segments_Accepted</i>
	<i>Local_Time</i>
<i>Local_Date</i>	
<i>UTC_Offset</i>	
<i>Daylight_Savings_Status</i>	
<i>APDU_Segment_Timeout</i>	
<i>APDU_Timeout</i>	
<i>Number_Of_APDU_Retries</i>	
Time_Synchronization_Recipients	
<i>Max_Master</i>	
<i>Max_Info_Frames</i>	
<i>Device_Address_Binding</i>	
<i>Database_Revision</i>	
<i>Configuration_Files</i>	
<i>Last_Restore_Time</i>	
Backup_Failure_Timeout	
<i>Active_COV_Subscriptions</i>	
UTC_Time_Synchronization_Recipients	
<i>Time_Synchronization_Interval</i>	
<i>Align_Intervals</i>	
<i>Interval_Offset</i>	
<i>Backup_Preparation_Time_proprietary</i>	
<i>Restore_Completion_Time_proprietary</i>	
<i>Restore_Preparation_Time_proprietary</i>	
<i>Backup_And_Restore_State_proprietary</i>	

Data Link Layer Options:

- BACnet IP, (Annex J)
- BACnet IP, (Annex J), Foreign Device
- ISO 8802-3, Ethernet (Clause 7)
- ANSI/ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ANSI/ATA 878.1, RS-485 ARCNET (Clause 8), baud rate(s) _____
- MS/TP master (Clause 9), baud rate(s): _____
- MS/TP slave (Clause 9), baud rate(s): _____
- Point-To-Point, EIA 232 (Clause 10), baud rate(s): _____
- Point-To-Point, modem, (Clause 10), baud rate(s): _____
- LonTalk, (Clause 11), medium: _____
- Other:

Device Address Binding:

Is static device binding supported? (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.) Yes No

Networking Options:

- Router, Clause 6 – Routing configurations: Ethernet-IP
- Annex H, BACnet Tunneling Router over IP
- BACnet/IP Broadcast Management Device (BBMD)
Does the BBMD support registrations by Foreign Devices? Yes No

Character Sets Supported:

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- ANSI X3.4 IBM™/Microsoft™ DBCS ISO 8859-1
- ISO 10646 (UCS-2) ISO 10646 (UCS-4) JIS C 6226

If this product is a communication gateway, describe the types of non-BACnet equipment/networks(s) that the gateway supports:

This product supports communications between BACnet and any third-party system to which EC-Net^{AX} can connect. Contact Distech Controls for a list of supported protocols.

Information and/or specifications published here are current as of the date of publication of this document. Distech Controls Inc. reserves the right to change or modify specifications without prior notice. The latest product specifications can be found by contacting our corporate headquarters, Brossard, Quebec. Products or features contained herein are covered by one or more U.S. or foreign patents. This document may be copied by parties who are authorized to distribute Distech Controls products in connection with distribution of those products, subject to the contracts that authorize such distribution. It may not otherwise, in whole or in part, be copied, photocopied, reproduced, translated, or reduced to any electronic medium or machine-readable form without prior written consent from Distech Controls Inc. Distech Controls and the Distech Controls logo are trademarks of Distech Controls, Inc. ©, Distech Controls Inc., 2011. All rights reserved.