

BACnet CONFORMANCE CERTIFICATE



No. BTL-30506

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.14. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 15.1 and the BTL Testing Policies, see Test Report number TC50890 of SoftDEL.

Product name (B-AWS)
EC-Net Supervisor
Model(s) EC-Net Supervisor 0, 1, 2, 3, 10, 100, UNL, SBS, MBS, LBS
Firmware version
4.4.94
Vendor
Distech Controls Inc.
4205 Place de Java
Brossard, Quebec, Canada, J4Y 0C4

This certificate is valid until **31-Mar-2024**.

21-Oct-2019

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body