

BACnet CONFORMANCE CERTIFICATE



No. BTL-30542

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.14. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 14.0 and the BTL Testing Policies, see Test Report number TC50833 of SoftDEL.

Product name (B-AAC)
SCY Series
Model(s) SCY-1DALI, SCY-2DALI
Firmware version
A: 1.0.0.0, F: 14.1.0.0
Vendor
Distech Controls, Inc.
4205 place de Java
Brossard, QC J4Y 0C4, Canada

This certificate is valid until **31-Mar-2023**.

07-Feb-2020

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann
Head of Certification Body