

BACnet CONFORMANCE CERTIFICATE



No. BTL-30678

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.17. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 16.1 and the BTL Testing Policies, see Test Report number TC51209 of Protocol Test Lab.

Product name (B-ASC)
WLC-4150. Dialog Lighting Control Unit
Model(s) WLC-4150
Firmware version
0.6.5
Vendor
Douglas Lighting Controls
3605 Gilmore Way #280
Burnaby, BC, Canada, V5G 4X5

This certificate is valid until **31-Mar-2026**.

11-Jan-2021

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann
Head of Certification Body