

TB7600 Series RTU/Heat Pump Communicating Thermostats BACnet Protocol Implementation Conformance Statement (PICS)

Topic:	BACnet Protocol Implementation Conformance Statement (PICS)
Date:	November 2006
Product Version:	3.5.05 (tested v2.1.03)
Applicable Products:	Honeywell TB7600 Series Thermostats
BACnet Protocol Revision:	2 (135-2001)

Contents

- Product Description..... 3
- BACnet Standardized Device Profile (Annex L):..... 3
- BACnet Interoperability Building Blocks Supported (Annex K):..... 3
- Segmentation Capability: 3
- Standard Object Types Supported:..... 4
- Data Link Layer Options: 4
- Device Address Binding: 5
- Networking Options:..... 5
- Character Sets Supported: 5

Product Description

The TB7600 PI thermostat family is specifically designed for single stage and multi-stage control of heating/cooling equipment such as rooftop and self-contained units. The product features an intuitive, menu-driven, back-lit LCD display which walks users through the programming steps, making the process extremely simple. Accurate temperature control is achieved due to the product's PI time proportional control algorithm, which virtually eliminates temperature offset associated with traditional, differential-based thermostats.

BACnet Standardized Device Profile (Annex L):

- BACnet Operator Workstation (B-OWS)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

BACnet Interoperability Building Blocks Supported (Annex K):

BACnet Interoperability Building Block	Supported
Data Sharing-ReadProperty-B (DS-RP-B)	<input checked="" type="checkbox"/>
Data Sharing-ReadPropertyMultiple-B (DS-RPM-B)	<input checked="" type="checkbox"/>
Data Sharing-WriteProperty-B (DS-WP-B)	<input checked="" type="checkbox"/>
Device Management-Dynamic Device Binding-B (DM-DDB-B)	<input checked="" type="checkbox"/>
Device Management-Dynamic Object Binding-B (DM-DOB-B)	<input checked="" type="checkbox"/>
Device Management-DeviceCommunicationControl-B (DM-DCC-B)	<input checked="" type="checkbox"/>

Segmentation Capability:

- Segmented Requests Supported Window Size: N/A
- Segmented Responses Supported Window Size: N/A

Standard Object Types Supported:

Object Type	Supported	Dynamically Creatable	Dynamically Deletable	Optional Properties Supported	Writable Properties
Analog Input	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Reliability	Out_of_Service
Analog Value	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Reliability	Present_Value ^a Out_of_Service ^a Object_Name ^b
Binary Input	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Reliability Active_Text Inactive_Text	Out_of_Service
Binary Value	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Reliability Active_Text Inactive_Text	Present_Value Out_of_Service
Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Max_Master Max_Info_frames	Object_Identifier Object_Name Max_Master
Group	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	N/A	N/A
Multi-state Value	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Reliability States_Text	Present_Value Out_of_Service
Schedule	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Weekly_schedule	Present_Value Weekly_Schedule

A: Present_Value and Out_of_Service properties are writable for every AV objects except :

- PI Heating Demand (AV20)
- PI Cooling Demand (AV21)
- Economizer Output (AV23)

B: Object_Name property is writable for 2 objects only:

- Room_Temperature (AV7)

Data Link Layer Options:

- BACnet IP, (Annex J)
- BACnet IP, (Annex J), Foreign Device
- ISO 8802-3, Ethernet (Clause 7) (10Base2, 10Base5, 10BaseT, Fiber)
- ANSI/ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ANSI/ATA 878.1, RS-485 ARCNET (Clause 8), baud rate(s):
- MS/TP master (Clause 9), baud rate(s): 9600, 19200, 38400, 76800 (Auto Baud)
- MS/TP slave (Clause 9), baud rate(s):
- Point-To-Point, EIA 232 (Clause 10), baud rate(s):
- Point-To-Point, modem, (Clause 10), baud rate(s):
- LonTalk, (Clause 11), medium:
- Other:

Device Address Binding:

Is static device binding supported? Yes No

(Necessary for two-way communication with MS/TP slaves and certain other devices.)

Networking Options:

Router	N/A
Annex H, BACnet Tunnelling	N/A
BACnet/IP Broadcast Management Device (BBMD)	N/A
Does the BBMD support registrations by Foreign Devices?	N/A

Character Sets Supported:

<input checked="" type="checkbox"/> ANSI X3.4	<input type="checkbox"/> IBM/Microsoft DBCS	<input type="checkbox"/> JIS C 6226
<input type="checkbox"/> ISO 10646 (ICS-4)	<input type="checkbox"/> ISO 10646 (UCS2)	<input type="checkbox"/> ISO 8859-1

If this product is a communication gateway, describe the types of non-BACnet equipment/network(s) that the gateway supports:

Not applicable.