BACnet CONFORMANCE CERTIFICATE

No. BTL-31672

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.3 and the BTL Testing Policies, see Test Report number TC51443 of Protocol Test Lab.

Product name (B-ASC)
Ultrasonic Energy Meter/Ultrasonic Flow Meter **Model(s)* HM*x*-CS*xxxx*4B*x***
Firmware version
Application Software Version: 20.05 (build 1) **Firmware Revision: 20.03 (build 1)**
Vendor
Honeywell International, Inc. **158 Nan Hai Road, TEDA** **Tianjin, 300457, P.R. of China**

* where x is according to listing information

This certificate is valid until **31-Mar-2030**.

30-Oct-2026
Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body

Issued on behalf of BACnet International
2900 Delk Road, Suite 700, PMB 321
Marietta, GA 30067, USA

Certification by WSPCert Dr.-Ing. Frank Bitter
Kapuzinerweg 7, 70374 Stuttgart, Germany

DAkkS Deutsche Akkreditierungsstelle D-ZE-11156-01-00