BACnet CONFORMANCE CERTIFICATE

No. BTL-31673

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.16. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.0 and the BTL Testing Policies, see Test Report number TC51346 of Protocol Test Lab.

Product name (B-AAC)
BACnet MSTP, IP and T1L VAV Controller **Model(s)* WEB-VA75*x*, WEB-VA00*x*, CPO-VA75*x*, CPO-VA00*x*, CLME-VA75*x*, CMLE-VA00*x*, VAA-VA75*x*, VAA-VA00*x*, VAA-VA75M24M-UUKL, VAA-VA423M24-UUKL**
Firmware version
Firmware Revision: 2.0.3.83
Vendor
Honeywell International Inc. **1405 Xenium Lane N Suite 230B** **Plymouth, MN 55441, USA**

* where x is according to listing information

This certificate is valid until **31-Mar-2029**.

30-Oct-2026
Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body

Issued on behalf of BACnet International
2900 Delk Road, Suite 700, PMB 321
Marietta, GA 30067, USA

Certification by WSPCert Dr.-Ing. Frank Bitter
Kapuzinerweg 7, 70374 Stuttgart, Germany

DAkkS Deutsche Akkreditierungsstelle D-ZE-11156-01-00