

April 11, 2014

Honeywell ComfortPoint™ Open Digital I/O Controller Protocol Implementation Conformance Statement (PICS)

Topic: BACnet Protocol Implementation Conformance Statement (PICS)
Date: April 2014
Version: 1.1
Applicable Products: ComfortPoint™ Open Digital I/O Controller (CPO-DIO),
Author: Li, Ting

This document contains Honeywell proprietary information. Information contained herein is to be used solely for the purpose submitted, and no part of this document or its contents shall be reproduced, published, or disclosed to a third party without the express permission of Honeywell International Sàrl.

HONEYWELL DISCLAIMS THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PURPOSE AND MAKES NO EXPRESS WARRANTIES EXCEPT AS MAY BE STATED IN ITS WRITTEN AGREEMENT WITH AND FOR ITS CUSTOMER.

In no event is Honeywell liable to anyone for any direct, special, or consequential damages. The information and specification in this document are subject to change without notice.

Honeywell ComfortPoint™ Open Digital I/O Controller

Annex A - Protocol Implementation Conformance Statement

Date: 11th, April, 2014

Vendor ID: 17

Vendor Name: Honeywell International Inc.

Product Name: Honeywell ComfortPoint™ Open Digital I/O Controller Controller

Product Model Number: CPO-DIO

Applications Software Version: N/A

Firmware Revision: CPO_DIO_BacNet_v2.5.3

BACnet Protocol Revision: 9

Product Description and Intended Use:

CPO-DIO is a Native BACnet® programmable digital controller that communicates via BACnet Master-Slave/Token-Passing (MS/TP) Protocol. CPO-DIO is designed to meet the requirements of a BACnet B-AAC (BACnet Advanced Application Controller) profile, Powerful and yet easily programmable. It can perform complex control, monitoring and energy management functions. This controller is ideally suitable for large plant room control application and remote input/output monitoring

BACnet Standardized Device Profile (Annex L):

- BACnet Operator Workstation (B-OWS)
- BACnet Advanced Operator Workstation (B-AWS)
- BACnet Operator Display (B-OD)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

BACnet Interoperability Building Blocks Supported (Annex K):

Data Sharing	Read Property-B	DS-RP-B
	Read Property Multiple-B	DS-RPM-B
	Write Property-B	DS-WP-B
	Write Property Multiple-B	DS-WPM-B
Alarm & Event Management	Change Of Value-B	DS-COV-B
	Notification Internal-B	AE-N-I-B
	Acknowledgement-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
Scheduling	Event Information –B	AE-INFO-B
	Scheduling Internal-B	SCHED-I-B
Device & Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	Device Communication Control-B	DM-DCC-B
	Time Synchronization-B	DM-TS-B
	UTC Time Synchronization-B	DM-UTC-B
	Reinitialize Device-B	DM-RD-B
Back-up and Restore-B	DM-BR-B	

Following device binding methods Supported by the controller

- Send Who-Is, receive I-Am (BIBB DM-DDB-A)
- Receive Who-Is, send I-Am (BIBB DM-DDB-B)
- Send Who-Has, receive I-Have (BIBB DM-DOB-A)
- Receive Who-Has, send I-Have (BIBB DM-DOB-B)
- Manual configuration of recipient device's network number and MAC address
- None of the above

Segmentation Capability:

Able to transmit segmented messages no ⇒ no Window Size ____
 Able to receive segmented messages no ⇒ no Window Size ____

Data Link Layer Options:

- BACnet IP, (Annex J)
- BACnet IP, (Annex J), Foreign Device
- ISO 8802-3, Ethernet (Clause 7)
- ANSI/ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ANSI/ATA 878.1, RS-485 ARCNET (Clause 8), baud rate(s)
- MS/TP master (Clause 9), baud rate(s): 9.6k, 19.2k, 38.4k, 76.8k bps
- MS/TP slave (Clause 9), baud rate(s):
- Point-To-Point, EIA 232 (Clause 10), baud rate(s):
- Point-To-Point, modem, (Clause 10), baud rate(s):
- LonTalk, (Clause 11), medium:
- Other:

Device Address Binding:

Is static device binding supported?
 (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.)
 Yes ⇒
 No

Networking Options:

- Router, Clause 6 - BACnet IP (Annex J) - MS/TP (3 MSTP Ports).
- Annex H, BACnet Tunneling Router over IP
- BACnet/IP Broadcast Management Device (BBMD)
 Does the BBMD support registrations by Foreign Devices? ⇒
 Yes
 No

Character Sets Supported:

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- ANSI X3.4
- IBM™/Microsoft™ DBCS
- JIS C 6226

- ISO 10646 (UCS-4)
- ISO 10646 (UCS-2)
- ISO 8859-1

Standard Object Types Supported:

	Object supported	Object dynamically creatable	Object dynamically deletable
ANALOG_INPUT	Y	N	N
ANALOG_OUTPUT	N	N	N
ANALOG_VALUE	Y	N	N
AVERAGING	N	N	N
BINARY_INPUT	Y	N	N
BINARY_OUTPUT	Y	N	N
BINARY_VALUE	Y	N	N
CALENDAR	Y	N	N
COMMAND	N	N	N
DEVICE	Y	N	N
EVENT_ENROLLMENT	N	N	N
FILE	Y	N	N
GROUP	N	N	N
LOOP	N	N	N
LIFE_SAFETY_DEVICE	N	N	N
LIFE_SAFETY_ZONE	N	N	N
MULTISTATE_INPUT	N	N	N
MULTISTATE_OUTPUT	N	N	N
MULTISTATE_VALUE	Y	N	N
NOTIFICATION_CLASS	Y	N	N
PROGRAM	N	N	N
SCHEDULE	Y	N	N
TRENDLOG	N	N	N
ACCUMULATOR	Y	N	N
PULSE_CONVERTER	N	N	N

Standard Objects and Properties Supported:

Accumulator Object

Readable Properties	Writable Properties
OBJECT_IDENTIFIRE	
OBJECT_NAME	
OBJECT_TYPE	
PRESENT_VALUE	PRESENT_VALUE
STATUS_FLAGS	
EVENT_STATE	
OUT_OF_SERVICE	OUT_OF_SERVICE
SCALE	
UNITS	
MAX_PRES_VALUE	MAX_PRES_VALUE
DESCRIPTION	

RELIABILITY	
PRESCALE	
VALUE_CHANGE_TIME	
VALUE_BEFORE_CHANGE	
VALUE_SET	VALUE_SET
PULSE_RATE	
HIGH_LIMIT	HIGH_LIMIT
LOW_LIMIT	LOW_LIMIT
LIMIT_MONITORING_INTERVAL	
NOTIFICATION_CLASS	
TIME_DELAY	TIME_DELAY
LIMIT_ENABLE	LIMIT_ENABLE
EVENT_ENABLE	EVENT_ENABLE
ACKED_TRANSITION	
NOTIFY_TYPE	NOTIFY_TYPE
EVENT_TIME_STAMPS	

Analog Input Object:

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	
OBJECT_TYPE	
PRESENT_VALUE	PRESENT_VALUE
STATUS_FLAGS	
EVENT_STATE	
OUT_OF_SERVICE	OUT_OF_SERVICE
UNITS	
DESCRIPTION	
RELIABILITY	
COV_INCREMENT	COV_INCREMENT
TIME_DELAY	TIME_DELAY
NOTIFICATION_CLASS	
HIGH_LIMIT	HIGH_LIMIT
LOW_LIMIT	LOW_LIMIT
DEADBAND	DEADBAND
LIMIT_ENABLE	LIMIT_ENABLE
EVENT_ENABLE	EVENT_ENABLE
ACKED_TRANSITIONS	
NOTIFY_TYPE	NOTIFY_TYPE
EVENT_TIME_STAMPS	

Analog Value Object:

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	
OBJECT_TYPE	
PRESENT_VALUE	PRESENT_VALUE
STATUS_FLAGS	
EVENT_STATE	
OUT_OF_SERVICE	OUT_OF_SERVICE
UNITS	

DESCRIPTION	
RELIABILITY	
COV_INCREMENT	COV_INCREMENT
TIME_DELAY	TIME_DELAY
NOTIFICATION_CLASS	
HIGH_LIMIT	HIGH_LIMIT
LOW_LIMIT	LOW_LIMIT
DEADBAND	DEADBAND
LIMIT_ENABLE	LIMIT_ENABLE
EVENT_ENABLE	EVENT_ENABLE
ACKED_TRANSITIONS	
NOTIFY_TYPE	NOTIFY_TYPE
EVENT_TIME_STAMPS	
PRIORITY_ARRAY	
RELINQUISH_DEFAULT	RELINQUISH_DEFAULT

Binary Input Object:

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	
OBJECT_TYPE	
PRESENT_VALUE	PRESENT_VALUE
STATUS_FLAGS	
EVENT_STATE	
OUT_OF_SERVICE	OUT_OF_SERVICE
POLARITY	
DESCRIPTION	
RELIABILITY	
INACTIVE_TEXT	
ACTIVET_TEXT	
ELAPSED_ACTIVE_TIME	ELAPSED_ACTIVE_TIME
TIME_OF_ACTIVE_TIME_RESET	
TIME_DELAY	TIME_DELAY
NOTIFICATION_CLASS	
ALARM_VALUE	ALARM_VALUE
EVENT_ENABLE	EVENT_ENABLE
ACKED_TRANSITIONS	
NOTIFY_TYPE	NOTIFY_TYPE
EVENT_TIME_STAMPS	

Binary Output Object:

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	
OBJECT_TYPE	
PRESENT_VALUE	PRESENT_VALUE
STATUS_FLAGS	
EVENT_STATE	
OUT_OF_SERVICE	OUT_OF_SERVICE
POLARITY	
PRIORITY_ARRAY	
RELINQUISH_DEFAULT	RELINQUISH_DEFAULT

DESCRIPTION	
RELIABILITY	
INACTIVE_TEXT	
ACTIVET_TEXT	
ELAPSED_ACTIVE_TIME	ELAPSED_ACTIVE_TIME
TIME_OF_ACTIVE_TIME_RESET	

Binary Value Object:

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	
OBJECT_TYPE	
PRESENT_VALUE	PRESENT_VALUE
STATUS_FLAGS	
EVENT_STATE	
OUT_OF_SERVICE	OUT_OF_SERVICE
DESCRIPTION	
RELIABILITY	
INACTIVE_TEXT	
ACTIVET_TEXT	
ELAPSED_ACTIVE_TIME	ELAPSED_ACTIVE_TIME
TIME_OF_ACTIVE_TIME_RESET	
TIME_DELAY	TIME_DELAY
NOTIFICATION_CLASS	
ALARM_VALUE	ALARM_VALUE
EVENT_ENABLE	EVENT_ENABLE
ACKED_TRANSITIONS	
NOTIFY_TYPE	NOTIFY_TYPE
EVENT_TIME_STAMPS	
PRIORITY_ARRAY	
RELINQUISH_DEFAULT	RELINQUISH_DEFAULT

Calendar Object:

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	
OBJECT_TYPE	
PRESENT_VALUE	
DATE_LIST	DATE_LIST
DESCRIPTION	

Device Object:

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	
OBJECT_TYPE	
SYSTEM_STATUS	
VENDOR_NAME	
VENDOR_IDENTIFIRE	
MODEL_NAME	
FIRMWARE_REVISION	
APPLICATION_SOFTWARE_VERSION	

PROTOCOL_VERSION	
PROTOCOL_REVISION	
PROTOCOL_SERVICES_SUPPORTED	
PROTOCOL_OBJECT_TYPES_SUPPORTED	
OBJECT_LIST	
MAX_APDU_LENGTH_ACCEPTED	
SEGMENTATION_SUPPORTED	
APDU_TIMEOUT	APDU_TIMEOUT
NUMBER_OF_APDU_RETRIES	
DEVICE_ADDRESS_BINDING	
DATABASE_REVISION	
LOCATION	
DESCRIPTION	
LOCAL_TIME	
LOCAL_DATE	
UTC_OFFSET	
DAYLIGHT_SAVING_STATUS	
MAX_MASTERS	MAX_MASTERS
MAX_INFO_FRAMES	
CONFIGURATION_FILES	
LAST_RESTORE_TIME	
BACKUP_FAILURE_TIMEOUT	BACKUP_FAILURE_TIMEOUT
ACTIVE_COV_SUBSCRIPTIONS	

File Object:

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	
OBJECT_TYPE	
FILE_TYPE	
FILE_SIZE	FILE_SIZE
MODIFICATION_DATE	
ARCHIVE	ARCHIVE
READ_ONLY	
FILE_ACCESS_METHOD	
DESCRIPTION	

Multi-State Value Object:

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	
OBJECT_TYPE	
PRESENT_VALUE	PRESENT_VALUE
STATUS_FLAGS	
EVENT_STATE	
OUT_OF_SERVICE	OUT_OF_SERVICE
DESCRIPTION	
RELIABILITY	
STATE_TEXT	
PRIORITY_ARRAY	
RELINQUISH_DEFAULT	RELINQUISH_DEFAULT
TIME_DELAY	TIME_DELAY

NOTIFICATION_CLASS	
ALARM_VALUES	ALARM_VALUES
FAULT_VALUES	FAULT_VALUES
EVENT_ENABLE	EVENT_ENABLE
ACKED_TRANSITIONS	
NOTIFY_TYPE	NOTIFY_TYPE
EVENT_TIME_STAMPS	

Notification Class Object:

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	
OBJECT_TYPE	
NOTIFICATION_CLASS	
PRIORITY	PRIORITY
RECIPIENT_LIST	RECIPIENT_LIST
ACK_REQUIRED	ACK_REQUIRED
DESCRIPTION	

Schedule Object:

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	
OBJECT_TYPE	
PRESENT_VALUE	PRESENT_VALUE
EFFECTIVE_PERIOD	EFFECTIVE_PERIOD
LIST_OF_OBJECT_PROPERTY_REFERENCE	LIST_OF_OBJECT_PROPERTY_REFERENCE
PRIORITY_FOR_WRITING	PRIORITY_FOR_WRITING
STATUS_FLAGS	
RELIABILITY	
OUT_OF_SERVICE	OUT_OF_SERVICE
SCHEDULE_DEFAULT	SCHEDULE_DEFAULT
DESCRIPTION	
WEEKLY_SCHEDULE	WEEKLY_SCHEDULE
EXCEPTION_SCHEDULE	EXCEPTION_SCHEDULE