

# BACnet CONFORMANCE CERTIFICATE



## No. BTL-30684

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.14. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 16.1 and the BTL Testing Policies, see Test Report number TC51219 of Protocol Test Lab.

Product name (B-AAC)
<b>BACnet MSTP Compact VAV Controller</b>
<b>Model(s) WEB-VA423B24N, CLMEVA423B24N, CPO-VA423B24N</b>
Firmware version
<b>2.0.1.03</b>
Vendor
<b>Honeywell International</b>
<b>1985 Douglas Drive</b>
<b>Golden Valley, MN 55422, USA</b>

This certificate is valid until **31-Mar-2026**.

**21-Jan-2021**

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann  
Head of Certification Body