

# BACnet CONFORMANCE CERTIFICATE



## No. BTL-31088-1

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.16. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.0 and the BTL Testing Policies, see Test Report number TC51346 of Protocol Test Lab.

Product name (B-AAC)
<b>BACnet MSTP and IP VAV controller</b>
<b>Model(s) WEB-/CPO-/CLME/VAA- VA75I24NM, VA75IB24NM, VA00IB24NM, VA75M24NM, VA75MB24NM, VA00MB24NM</b>
Firmware version
<b>2.0.3.83</b>
Vendor
<b>Honeywell International Inc. 1405 Xenium Lane N, Suite 230B Plymouth, MN 55441, USA</b>

This certificate is valid until **31-Mar-2029**.

**20-Dec-2023**

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann  
Head of Certification Body