

BACnet CONFORMANCE CERTIFICATE



No. BTL-30711

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.14. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 14.0 and the BTL Testing Policies, see Test Report number TC50706 of SoftDEL.

Product name (B-ASC)
BCU/BLC/BR/ELV series programmable logic controller
Model(s)* BCU-x, BLC-x, BCX-x, MGP-x, ELV-x, BVC-x, BR-50, BR-10, BR-MBUS4, BG-TCU
Software version
M128 V4.00A
Vendor
Hysine Controls
No. 1, Gaoxin 3rd Street, Huilongguan international information industry base, Changping District Beijing City, China

* where x is according to listing information

This certificate is valid until **31-Mar-2022**.

24-Mar-2021

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body