


BACnet CONFORMANCE CERTIFICATE



No. BTL-30652

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.12. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 14.0 and the BTL Testing Policies, see Test Report number TC50607 of SoftDEL.



Product name (B-ASC)

Intesis Air Conditioning Interface Series

Model(s) Daikin Domestic & VRV / Mitsubishi Electric / Mitsubishi Heavy Ind. / Panasonic Etherea & ECOi and PACi / Toshiba VRF to BACnet IP/MSTP or only BACnet MSTP, Fujitsu RAC and VRF / Midea Commercial & VRF to BACnet MSTP

Software version

F: 12.1.1.3

Vendor

Intesis (HMS Industrial Networks, SLU)

**Milà i Fontanals, 7
Igualada, Barcelona, 08700 Spain**

This certificate is valid until **31-Mar-2022**.

19-Oct-2020

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body