


BACnet CONFORMANCE CERTIFICATE



No. BTL-30715

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.12. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 14.0 and the BTL Testing Policies, see Test Report number TC50607 of SoftDEL.

Product name (B-ASC)

Intesis Air Conditioning Interface Series

Model(s) Daikin Domestic & VRV / Mitsubishi Electric / Mitsubishi Heavy Ind. / Panasonic Etherea & ECOi and PACi / Toshiba VRF and Digital to BACnet IP/MSTP or only BACnet MSTP; Fujitsu RAC and VRF / Midea Commercial & VRF / Universal Infrared AC to BACnet MSTP; Hitachi VRF to BACnet IP/MSTP

Software version

F: 12.1.1.3

Vendor

Intesis (HMS Industrial Networks, SLU)

Milà i Fontanals, 7

Igualada, Barcelona, 08700 Spain

This certificate is valid until **31-Mar-2022**.

19-Apr-2021

Date of Initial Certification

Dipl.-Ing. G. Weinmann

Head of Certification Body

Certification verified by WSPCert
Dr.-Ing. Frank Bitter
Kapuzinerweg 7, 70374 Stuttgart, Germany
Phone: +49 (0)711 9539220, email: info@wspcert.de