

BACnet CONFORMANCE CERTIFICATE



No. BTL-31022

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 20.0 and the BTL Testing Policies, see Test Report number TC51330 of Protocol Test Lab.

Product name (B-ASC)

Intesis Air Conditioning Interface Series 2E

Model(s) Universal Infrared AC, Daikin Domestic, Daikin VRV and Sky, Fujitsu RAC & VRF, Hitachi VRF systems, Mitsubishi Heavy Ind. FD & VRF, Mitsubishi Electric Domestic Mr.SI.& CityM, Panasonic Etherea AC to BACnet MSTP

Software version

BACnet Firmware Revision: 15.0.0.0

Vendor

Intesis (HMS Industrial Networks SLU)

**Milà i Fontanals 7
08700 Igualada, Spain**

This certificate is valid until **31-Mar-2028**.

23-May-2023

Date of Initial Certification

A handwritten signature in blue ink, appearing to read 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann
Head of Certification Body