

# BACnet CONFORMANCE CERTIFICATE



## No. BTL-31509

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.19. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 26.0 and the BTL Testing Policies, see Test Report number TC51498 of Protocol Test Lab.

Product name (B-AAC)
<b>Metasys VAV Box Controller (CVM)</b>
<b>Model(s) M4-CVM03050-0, M4-CVM03050-0P</b>
Firmware version
<b>12.0.1.34</b>
Vendor
<b>Johnson Controls</b>
<b>5757 N. Green Bay Ave</b>
<b>Milwaukee, WI 53209, USA</b>

This certificate is valid until **31-Mar-2031**.

**12-Mar-2026**

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann  
Head of Certification Body