

BACnet CONFORMANCE CERTIFICATE



No. BTL-31631

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.19. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.3 and the BTL Testing Policies, see Test Report number TC51467 of Protocol Test Lab.

Product name (B-AWS,B-BC,B-SCHUB)
NAE85 Network Automation Engine, LCS85 LonWorks® Control Server
Model(s) MS-NXE85SW-0, MS-NXE85SW-6, MS-LCS85SW-0, MS-LCS85SW-6
Firmware version
15.0.2.192
Vendor
Johnson Controls
5757 N Green Bay Ave
Glendale, WI 53209, USA

This certificate is valid until **31-Mar-2031**.

04-Sep-2026

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body