

# BACnet CONFORMANCE CERTIFICATE



**No. BTL-30426**

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 15.1 and the BTL Testing Policies, see Test Report number TC50905 of SoftDEL.

Product name (B-AAC)
<b>Programmable Controller VAV (PCV)</b>
<b>Model(s) FX-PCV1930-0</b>
Firmware version
<b>8.0.0.1256</b>
Vendor
<b>Johnson Controls</b> <b>507 E. Michigan St</b> <b>Milwaukee, WI 53202, USA</b>

This certificate is valid until **31-Mar-2024**.

**23-May-2019**

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann  
Head of Certification Body