

BACnet CONFORMANCE CERTIFICATE



No. BTL-30896-1

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.18. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 18.1 and the BTL Testing Policies, see Test Report number TC51238 of Protocol Test Lab.

Product name (B-BC,B-RTR,B-SCHUB)
Network Automation Engine (NAE)
Model(s) MS-NAE5510-3, MS-NAE5511-3, MS-NAE5520-3, MS-NAE5521-3
Firmware version
12.0.0.3189
Vendor
Johnson Controls Inc.
507 E. Michigan St
Milwaukee, WI 53202, USA

This certificate is valid until **31-Mar-2027**.

02-Sep-2022

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body