

Protocol Implementation Conformance Statement (Normative)

BACnet Protocol Implementation Conformance Statement



BAC-8XXX
Application Specific Controller

**BACnet Protocol Implementation Conformance Statement
(BACnet Testing Laboratories Version)**

Date: 09-14-11

Vendor Name: KMC Controls

Product Name: ASC for Titus VAV

Product Model Number: BAC-8XXX

Applications Software Version: APP1.0.7.0

Firmware Revision: R1.0.0.5

BACnet Protocol Revision: 135-2008 Version:1, Revision:7

Product Description:

The BAC-8XXX is an application specific direct digital control actuator (B-ASC) that provides precise monitoring and control of connected points . Model specific I/O:

BAC-8001, BAC-8201: Single Duct Cooling only

Inputs: Discharge Air Temp, Space Temp, Setpoint, and Air Flow.

Binary Outputs: Actuator Drive Clockwise and Actuator Drive Counter Clockwise,

BAC-8005, BAC-8205: Single Duct with Cooling/Heating

Inputs: Discharge Air Temp, Space Temp, Setpoint, and Air Flow.

Analog Outputs: Analog Heat and Fan Speed.

Binary Outputs: Actuator Drive Clockwise and Actuator Drive Counter Clockwise,
Fan Start/Stop, Heating Stage 1, Heating Stage 2 and Heating Stage 3.

BAC-8007, BAC-8207: Dual Duct with Cooling and Heating,

Inputs: Discharge Air Temp, Space Temp, Setpoint, Primary Air Flow, Secondary Air Flow,
Primary Damper, Position, Secondary Damper position and CO2.

Analog Outputs: Analog Heat and Fan Speed.

Binary Outputs: Actuator Drive Clockwise and Actuator Drive Counter Clockwise,
Fan Start/Stop, Secondary Actuator Clockwise, Secondary Actuator Counter
Clockwise and Heating Stage/Lighting.

List all BACnet Interoperability Building Blocks supported (see Annex K in BACnet 2001):

DS-RP-A, DS-RP-B, DS-RPM-B, DS-WP-A, DS-WP-B, DS-WPM-B, DM-DDB-A, DM-DDB-B,
DM-DCC-B, DM-DOB-B, DM-TS-B, DM-RD-B

Which of the following device binding methods does the product support? (check one or more)

- Send Who-Is, receive I-Am (BIBB DM-DDB-A)
- Receive Who-Is, send I-Am (BIBB DM-DDB-B)
- Send Who-Has, receive I-Have (BIBB DM-DOB-A)
- Receive Who-Has, send I-Have (BIBB DM-DOB-B)
- Manual configuration of recipient device's network number and MAC address
- None of the above

Standard Object Types Supported:

OBJECT	CREATABLE	DELETABLE	OPTIONAL PROPERTIES
Analog Input	No	No	Description, Device_Type
Analog Output	No	No	Description, Device_Type

BTL Product Testing and Listing Program Application Form - Revised January 3, 2003

Analog value	No	No	Description, Priority_Array, Relinquish_Default
Binary Output	No	No	Active_Text, Description, Device_Type, Inactive_Text
Binary Value	No	No	Active_Text, Description, Inactive_Text, Priority_Array, Relinquish_Default
Loop	No	No	Bias, Derivative_Constant, Derivative_Constant_Units, Description, Integral_Constant, Integral_Constant_Units, Maximum_Output, Minimum_Output, Proportional_Constant, Proportional_Constant_Units
Program	No	No	Description, Description_Of_Halt, Program_Location, Reason_For_Halt
File	No	No	Description
Device	No	No	Description, Local_Date, Local_Time, Location, Max_Info_Frames, Max_Master,
Multi-State Value	No	No	Description, Priority_Array, Relinquish_Default, State_Text,

Data Link Layer Options (check all that are supported):

- BACnet IP, (Annex J)
 - Able to register as a Foreign Device
- ISO 8802-3, Ethernet (Clause 7)
- ANSI/ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ANSI/ATA 878.1, RS-485 ARCNET (Clause 8), baud rate(s) _____
- MS/TP master (Clause 9), baud rate(s): 9600, 19200, 38400, 76800
- MS/TP slave (Clause 9), baud rate(s): 9600, 19200, 38400, 76800
- Point-To-Point, EIA 232 (Clause 10), baud rate(s): _____
- Point-To-Point, modem, (Clause 10), baud rate(s): _____
- LonTalk, (Clause 11), medium: _____
- Other: _____

Networking Options (check all that are supported):

- Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.:

- Annex H.3, BACnet Tunneling Router over UDP/IP
- BACnet/IP Broadcast Management Device (BBMD)
 - Does the BBMD support registrations by Foreign Devices? Yes No

Segmentation Capability (check all that apply):

- Able to transmit segmented messages Window Size _____
- Able to receive segmented messages Window Size _____

Character Sets Supported (check all that apply):

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- ANSI X3.4 IBM™/Microsoft™ DBCS ISO 8859-1
- ISO 10646 (UCS-2) ISO 10646 (ICS-4) JIS C 6226

If this product is a communication gateway, describe the non-BACnet equipment/network(s) that the gateway supports:

Include any addition information about the product's BACnet capabilities relevant to interoperability:

Protocol Implementation Conformance Statement (Normative)

BACnet Protocol Implementation Conformance Statement



**SimplyVAV
BAC-8XXX
Application Specific Controller**

**BACnet Protocol Implementation Conformance Statement
(BACnet Testing Laboratories Version)**

Date: 03-14-14
Vendor Name: KMC Controls
Product Name: SimplyVAV
Product Model Number: BAC-8XXX
Applications Software Version: APP1.0.7.0 **Firmware Revision:** R1.0.0.5
BACnet Protocol Revision: 135-2008 Version:1, Revision:7

Product Description:

The BAC-8XXX is an application specific direct digital control actuator (B-ASC) that provides precise monitoring and control of connected points. Model specific I/O:

BAC-8001: Single Duct Cooling/Heating

Inputs: Discharge Air Temp, Space Temp, Setpoint, and Air Flow.
 Binary Outputs: Actuator Drive Clockwise and Actuator Drive Counter Clockwise,

BAC-8005, BAC-8205: Single Duct Fan & Reheat

Inputs: Discharge Air Temp, Space Temp, Setpoint, and Air Flow (BAC-8205 adds position).
 Analog Outputs: Analog Heat and Fan Speed.
 Binary Outputs: Actuator Drive Clockwise and Actuator Drive Counter Clockwise,
 Fan Start/Stop, Heating Stage 1, Heating Stage 2 and Heating Stage 3.

BAC-8007: Dual Duct

Inputs: Discharge Air Temp, Space Temp, Setpoint, Primary Air Flow, Secondary Air Flow,
 Primary Damper, Position, Secondary Damper position and CO2.
 Analog Outputs: Analog Heat and Fan Speed.
 Binary Outputs: Actuator Drive Clockwise and Actuator Drive Counter Clockwise,
 Fan Start/Stop, Secondary Actuator Clockwise, Secondary Actuator Counter
 Clockwise and Heating Stage/Lighting.

List all BACnet Interoperability Building Blocks supported (see Annex K in BACnet 2001):

DS-RP-A, DS-RP-B, DS-RPM-B, DS-WP-A, DS-WP-B, DS-WPM-B, DM-DDB-A, DM-DDB-B,
 DM-DCC-B, DM-DOB-B, DM-TS-B, DM-RD-B

Which of the following device binding methods does the product support? (check one or more)

- Send Who-Is, receive I-Am (BIBB DM-DDB-A)
- Receive Who-Is, send I-Am (BIBB DM-DDB-B)
- Send Who-Has, receive I-Have (BIBB DM-DOB-A)
- Receive Who-Has, send I-Have (BIBB DM-DOB-B)
- Manual configuration of recipient device's network number and MAC address
- None of the above

Standard Object Types Supported:

OBJECT	CREATABLE	DELETABLE	OPTIONAL PROPERTIES
Analog Input	No	No	Description, Device_Type
Analog Output	No	No	Description, Device_Type

BTL Product Testing and Listing Program Application Form - Revised January 3, 2003

Analog value	No	No	Description, Priority_Array, Relinquish_Default
Binary Output	No	No	Active_Text, Description, Device_Type, Inactive_Text
Binary Value	No	No	Active_Text, Description, Inactive_Text, Priority_Array, Relinquish_Default
Loop	No	No	Bias, Derivative_Constant, Derivative_Constant_Units, Description, Integral_Constant, Integral_Constant_Units, Maximum_Output, Minimum_Output, Proportional_Constant, Proportional_Constant_Units
Program	No	No	Description, Description_Of_Halt, Program_Location, Reason_For_Halt
File	No	No	Description
Device	No	No	Description, Local_Date, Local_Time, Location, Max_Info_Frames, Max_Master,
Multi-State Value	No	No	Description, Priority_Array, Relinquish_Default, State_Text,

Data Link Layer Options (check all that are supported):

- BACnet IP, (Annex J)
 - Able to register as a Foreign Device
- ISO 8802-3, Ethernet (Clause 7)
- ANSI/ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ANSI/ATA 878.1, RS-485 ARCNET (Clause 8), baud rate(s) _____
- MS/TP master (Clause 9), baud rate(s): 9600, 19200, 38400, 76800
- MS/TP slave (Clause 9), baud rate(s): 9600, 19200, 38400, 76800
- Point-To-Point, EIA 232 (Clause 10), baud rate(s): _____
- Point-To-Point, modem, (Clause 10), baud rate(s): _____
- LonTalk, (Clause 11), medium: _____
- Other: _____

Networking Options (check all that are supported):

- Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.:

- Annex H.3, BACnet Tunneling Router over UDP/IP
- BACnet/IP Broadcast Management Device (BBMD)
 - Does the BBMD support registrations by Foreign Devices? Yes No

Segmentation Capability (check all that apply):

- Able to transmit segmented messages Window Size _____
- Able to receive segmented messages Window Size _____

Character Sets Supported (check all that apply):

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- ANSI X3.4 IBM™/Microsoft™ DBCS ISO 8859-1
- ISO 10646 (UCS-2) ISO 10646 (ICS-4) JIS C 6226

If this product is a communication gateway, describe the non-BACnet equipment/network(s) that the gateway supports:

Include any addition information about the product's BACnet capabilities relevant to interoperability:

Protocol Implementation Conformance Statement (Normative)

BACnet Protocol Implementation Conformance Statement



RTU

(KMC Controls BAC-8304)

Application Specific Controller (B-ASC)

**BACnet Protocol Implementation Conformance Statement
(BACnet Testing Laboratories Version)**

Date: 06-03-13

Vendor Name: KMC Controls

Product Name: RTU

Product Model Number: KMC Controls BAC-8304

Applications Software Version: APP1.0.10.0

Firmware Revision: R1.0.0.3

BACnet Protocol Revision: 135-2008 Version:1, Revision:7

Product Description:

The BAC-8304 is an application specific direct digital control actuator (B-ASC) that provides precise monitoring and control of connected points. It is designed for the application of 2H/2C RTU with economizer and occupancy enable. It has four analog inputs, a modular connection for an STE-8001 digital sensor/interface, and six single-stage optically isolated triac outputs.

List all BACnet Interoperability Building Blocks supported (see Annex K in BACnet 2001):

DS-RP-A, DS-RP-B, DS-RPM-B, DS-WP-A, DS-WP-B, DS-WPM-B, DM-DDB-A, DM-DDB-B, DM-DCC-B, DM-DOB-B, DM-TS-B, DM-RD-B

Which of the following device binding methods does the product support? (check one or more)

- Send Who-Is, receive I-Am (BIBB DM-DDB-A)
- Receive Who-Is, send I-Am (BIBB DM-DDB-B)
- Send Who-Has, receive I-Have (BIBB DM-DOB-A)
- Receive Who-Has, send I-Have (BIBB DM-DOB-B)
- Manual configuration of recipient device's network number and MAC address
- None of the above

Standard Object Types Supported:

OBJECT	CREATABLE	DELETABLE	OPTIONAL PROPERTIES
Analog Input	No	No	Description, Device_Type
Analog Output	No	No	Description, Device_Type
Analog value	No	No	Description, Priority_Array, Relinquish_Default
Binary Output	No	No	Active_Text, Description, Device_Type, Inactive_Text
Binary Value	No	No	Active_Text, Description, Inactive_Text, Priority_Array, Relinquish_Default
Loop	No	No	Bias, Derivative_Constant, Derivative_Constant_Units, Description, Integral_Constant, Integral_Constant_Units, Maximum_Output, Minimum_Output, Proportional_Constant, Proportional_Constant_Units
Program	No	No	Description, Description_Of_Halt, Program_Location, Reason_For_Halt

BTL Product Testing and Listing Program Application Form - Revised January 3, 2003

File	No	No	Description
Device	No	No	Description, Local_Date, Local_Time, Location, Max_Info_Frames, Max_Master,
Multi-State Value	No	No	Description, Priority_Array, Relinquish_Default, State_Text,

Data Link Layer Options (check all that are supported):

- BACnet IP, (Annex J)
 - Able to register as a Foreign Device
- ISO 8802-3, Ethernet (Clause 7)
- ANSI/ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ANSI/ATA 878.1, RS-485 ARCNET (Clause 8), baud rate(s) _____
- MS/TP master (Clause 9), baud rate(s): 9600, 19200, 38400, 76800
- MS/TP slave (Clause 9), baud rate(s): 9600, 19200, 38400, 76800
- Point-To-Point, EIA 232 (Clause 10), baud rate(s): _____
- Point-To-Point, modem, (Clause 10), baud rate(s): _____
- LonTalk, (Clause 11), medium: _____
- Other: _____

Networking Options (check all that are supported):

- Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.: _____
- Annex H.3, BACnet Tunneling Router over UDP/IP
- BACnet/IP Broadcast Management Device (BBMD)
 - Does the BBMD support registrations by Foreign Devices? Yes No

Segmentation Capability (check all that apply):

- Able to transmit segmented messages Window Size _____
- Able to receive segmented messages Window Size _____

Character Sets Supported (check all that apply):

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- ANSI X3.4 IBM™/Microsoft™ DBCS ISO 8859-1
- ISO 10646 (UCS-2) ISO 10646 (ICS-4) JIS C 6226

If this product is a communication gateway, describe the non-BACnet equipment/network(s) that the gateway supports:

Include any addition information about the product's BACnet capabilities relevant to interoperability:
