

# BACnet CONFORMANCE CERTIFICATE



## No. BTL-31463

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.26. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 26.0 and the BTL Testing Policies, see Test Report number BAC01040 of TÜV SÜD Industrie Service GmbH.

Product name (B-BC)
<b>BACnet L-IOB Controller and I/O Modules</b>
<b>Model(s) LIOB-550, LIOB-551, LIOB-552, LIOB-553, LIOB-554, LIOB-560, LIOB-562, LIOB-580, LIOB-581, LIOB-582, LIOB-583, LIOB-584, LIOB-585, LIOB-586, LIOB-587, LIOB-588, LIOB 589, LIOB-590, LIOB-591, LIOB-592, LIOB-593, LIOB-594, LIOB-595, LIOB-596, LIOB-AIR1, LIOB-AIR2, LIOB-AIR13, LIOB AIR20</b>
Firmware version
<b>8.6</b>
Vendor
<b>LOYTEC electronics GmbH</b>
<b>Blumengasse 35</b>
<b>1170 Wien, Austria</b>

This certificate is valid until **31-Mar-2031**.

**22-Dec-2025**

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann  
Head of Certification Body