


BACnet CONFORMANCE CERTIFICATE



No. BTL-31405

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.19. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.3 and the BTL Testing Policies, see Test Report number TC51428 of Protocol Test Lab.

Product name (B-AWS)
WebCTRL for OEM
Model(s) WC-OEM, WC-OEM1, WC-OEM10
Software version
10.0
Vendor
OEMCtrl
1150 Roberts Blvd.
Kennesaw, GA 30144, USA

This certificate is valid until **31-Mar-2031**.

12-Sep-2025

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', written over a horizontal line.

Dipl.-Ing. G. Weinmann
Head of Certification Body