

BACnet CONFORMANCE CERTIFICATE



No. BTL-30536

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 15.2 and the BTL Testing Policies, see Test Report number 19.1122.001.010 of iHomeLab.

Product name (B-OWS)
Piscada BAS
Model(s) Piscada BAS 3.0
Firmware version
3.0.0
Vendor
Piscada AS
Ingvald Ystgaardsvei 1c
7047 Trondheim, Norway

This certificate is valid until **31-Mar-2025**.

24-Jan-2020

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann
Head of Certification Body