

BACnet CONFORMANCE CERTIFICATE



No. BTL-31146

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.16. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.1 and the BTL Testing Policies, see Test Report number TC51390 of Protocol Test Lab.

Product name (B-AAC)
Antec Controls
Model(s) LUME20
Firmware version
1.0.0
Vendor
Price Industries
638 Raleigh Street
Winnipeg, MB R2K 3Z9, Canada

This certificate is valid until **31-Mar-2029**.

28-Mar-2024

Date of Initial Certification

A handwritten signature in blue ink, appearing to read 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann
Head of Certification Body