PICS statement PIC / PIC SD



ANNEX A BACnet Protocol Implementation Conformance Statement

Date: 2018 - 06 - 13 Vendor Name: Price Industries/ (BACnet Vendor ID: 158) Product Name: PIC / PIC SD Product Model Number: PIC / PIC SD Application Software Version: PS 2.81–p1 Firmware Revision: 3.00

BACnet Protocol Revision: 7

Product Description:

The Price Intelligent Controller is a universal DDC control package that offers a new level of zone control. An advanced and configurable proportional integral controller allows for exceptional user comfort and energy efficiency.

BACnet Standardized Device Profile (Annex L):

BACnet Operator Workstation (B-OWS)
 BACnet Building Controller (B-BC)
 BACnet Advanced Application Controller (B-AAC)
 BACnet Application Specific Controller (B-ASC)
 BACnet Smart Sensor (B-SS)
 BACnet Smart Actuator (B-SA)

List all BACnet Interoperability Building Blocks Supported (Annex K): ReadProperty, WriteProperty, DeviceCommunicationControl, ReinitializeDevice, IAM, WhoIs, WhoHas

Segmentation Capability:

Segmented requests supportedSegmented responses supported

Standard Object Types Supported:

Analog Input, Analog Value, Device.

PIC does not support dynamic creation of objects using the CreateObject service. PIC does not support dynamic deletion of objects using the DeleteObject service.

Data Link Layer Options:

BACnet IP, (Annex J)
BACnet IP, (Annex J), Foreign Device
ISO 8802-3, Ethernet (Clause 7)
ANSI/ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
ANSI/ATA 878.1, RS-485 ARCNET (Clause 8), baud rate(s)
MS/TP master (Clause 9), baud rate(s): 9600, 19200, 38400, 76800
MS/TP slave (Clause 9), baud rate(s):
Point-To-Point, EIA 232 (Clause 10), baud rate(s):
Point-To-Point, modem, (Clause 10), baud rate(s):
LonTalk, (Clause 11), medium:
Other:

Device Address Binding:

PICS statement PIC / PIC SD



Is static device binding supported? (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.) \Box Yes \boxtimes No

Networking Options:

 Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.
 Annex H, BACnet Tunneling Router over IP
 BACnet/IP Broadcast Management Device (BBMD) Does the BBMD support registrations by Foreign Devices?
 Yes
 No

Character Sets Supported:

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

🖾 ANSI X3.4	\square IBM TM /Microsoft TM DBCS	□ ISO 8859-1
□ ISO 10646 (UCS-2)	□ ISO 10646 (UCS-4)	□ JIS C 6226

If this product is a communication gateway, describe the types of non-BACnet equipment/networks(s) that the gateway supports: Not applicable to PIC