

BACnet® Protocol Implementation Conformance Statement

Products

Product Name	Model #	Protocol Revision	Software Version	Firmware Version	Tested
MACH-ProWebCom	MPW-C	14	2.02	8.08	✓

Vendor Information

Reliable Controls Corporation
120 Hallowell Road
Victoria, B.C. Canada
V9A 7K2
www.reliablecontrols.com

Product Description

Publish your building automation system to the Web quickly and easily with the Reliable Controls® MACH-ProWebCom™. The first 3-in-1 device of its kind, the MACH-ProWebCom combines a BTL-listed BACnet® Building Controller (B-BC), a BTL-listed BACnet Operator Workstation (B-OWS), and a powerful web server into a single package with an installed footprint of a typical building controller. The MACH-ProWebCom provides high speed 10/100 Ethernet, SMART-Net communications, expandable I/O, and protocol support for BACnet, SMTP, and Modbus RTU and TCP (both master and slave). Points are added to the MACH-ProWebCom using convenient MACH-ProPoint™ expansion modules. Up to 8 MACH-ProPoint expansion modules can be added to each MACH-ProWebCom controller.

BACnet® Protocol Implementation Conformance Statement

Product Tested

Model #	Product Name
MPW-C	MACH-ProWebCom

BACnet Standard Device Profile

Product	Device Profile
MACH-ProWebCom™	BACnet Building Controller (B-BC) BACnet Operator Workstation (B-OWS)

Segmentation Capability

Segmentation	Supported	Window Size
Able to transmit segmented messages	Yes	8
Able to receive segmented messages	Yes	8

Data Link Layer Options

Data Link	Options
Ethernet (ISO 8802-3)	
BACnet/IP	x 2
MS/TP Master	9600, 19200, 38400, 76800
AUX-Net (MS/TP) Master	9600, 19200, 38400, 76800
Point-To-Point	9600, 19200, 38400, 57600, 115200

Device Address Binding

Static Binding Supported	No
--------------------------	----

Broadcast Capability

BACnet/IP Broadcast Management Device (BBMD)
Yes, supports registration by foreign devices.

Networking Options

Router Options	
BACnet/IP1 <-> BACnet/IP2	BACnet/IP2 <-> PTP
BACnet/IP1 <-> Ethernet	Ethernet <-> MS/TP-Net
BACnet/IP1 <-> MS/TP-Net	Ethernet <-> AUX-Net
BACnet/IP1 <-> AUX-Net	Ethernet <-> PTP
BACnet/IP1 <-> PTP	MS/TP-Net <-> AUX-Net
BACnet/IP2 <-> Ethernet	MS/TP-Net <-> PTP
BACnet/IP2 <-> MS/TP-Net	AUX-Net <-> PTP
BACnet/IP2 <-> AUX-Net	

Character Sets

Character Sets Supported	UTF-8
--------------------------	-------

Supported BIBBs

Supported BIBBs	BIBB Name
DS-RP-A	Data Sharing-ReadProperty-A
DS-RP-B	Data Sharing-ReadProperty-B
DS-RPM-A	Data Sharing-ReadPropertyMultiple-A
DS-RPM-B	Data Sharing-ReadPropertyMultiple-B
DS-WP-A	Data Sharing-WriteProperty-A
DS-WPM-A	Data-Sharing-WritePropertyMultiple-A
DS-WP-B	Data Sharing-WriteProperty-B
DS-WPM-B	Data Sharing-WritePropertyMultiple-B
DS-V-A	Data-Sharing-View-A
DS-M-A	Data-Sharing-Modify-A
DS-COV-A	Data Sharing-COV-A
DS-COV-B	Data Sharing-COV-B
DS-COVU-A	Data Sharing-COV-Unsolicited-A
DS-COVU-B	Data Sharing-COV-Unsolicited-B
AE-N-A	Alarm and Event-Notification-A
AE-N-E-B	Alarm and Event-Notification External-B
AE-N-I-B	Alarm and Event-Notification Internal-B
AE-ACK-A	Alarm and Event-ACK-A
AE-ACK-B	Alarm and Event-ACK-B
AE-ASUM-B	Alarm and Event-Alarm Summary-B
AE-ESUM-B	Alarm and Event-Enrollment Summary-B
AE-INFO-B	Alarm and Event-Information-B
AE-AS-A	Alarm and Event Management-Alarm Summary View-A
AE-VM-A	Alarm and Event Management-View and Modify-A
AE-VN-A	Alarm and Event-View Notification-A
SCHED-VM-A	Schedule-View and Modify-A
SCHED-I-B	Scheduling-Internal-B
SCHED-E-B	Scheduling-External-B
TV-A	Trending-View-A
TVMT-I-B	Trending-Viewing and Modifying Trends Internal-B
TVMT-E-B	Trending-Viewing and Modifying Trends External-B
T-ATR-B	Trending-Automated Trend Retrieval-B
TVMMV-I-B	Trending-Viewing and Modifying Multiple Value Internal-B
TVMMV-E-B	Trending-Viewing and Modifying Multiple Value External-B
T-AMVR-B	Trending-Automated Multiple Value Retrieval-B
DM-DDB-A	Device Management-Dynamic Device Binding-A
DM-DDB-B	Device Management-Dynamic Device Binding-B
DM-DOB-B	Device Management-Dynamic Object Binding-B
DM-DCC-B	Device Management-Device Communication Control-B
DM-ATS-A	Device Management-Automatic Time Synchronization-A
DM-MTS-A	Device Management-Manual Time Synchronization-A
DM-TS-A	Device Management-Time Synchronization-A
DM-TS-B	Device Management-Time Synchronization-B
DM-UTC-A	Device Management-UTCTimeSynchronization-A
DM-UTC-B	Device Management-UTCTimeSynchronization-B
DM-RD-B	Device Management-Reinitialize Device-B
DM-BR-B	Device Management-Backup and Restore-B
DM-R-B	Device Management-Restart-B
DM-LM-A	Device Management-List Manipulation-A
DM-LM-B	Device Management-List Manipulation-B
DM-OCD-B	Device Management-Object Creation and Deletion-B
NM-RC-B	Network Management-Router Configuration-B

Supported Standard Object Types

Object Type	Dynamic Creation	Dynamic Deletion	Optional Properties Supported	Write Properties
Device	No	No	Local_Time, Local_Date, UTC_Offset, Max_Master, Max_Info_Frames, Description, APDU_Segment_Timeout, Daylight_Savings_Status, Max_Segments_Accepted, Configuration_Files, Last_Restore_Time, Backup_Failure_Timeout, Time_Synchronization_Recipients, UTC_Time_Synchronization_Recipients, Time_Synchronization_Interval, Interval_Offset, Align_Intervals, Last_Restart_Reason, Time_Of_Device_Restart, Restart_Notification_Recipients, Active_COV_Subscriptions, Location	UTC_Offset, Max_Info_Frames, Object_Name, Description, APDU_Segment_Timeout, APDU_Timeout, Number_Of_APDU_Retries, Backup_Failure_Timeout, Time_Synchronization_Recipients, UTC_Time_Synchronization_Recipients, Time_Synchronization_Interval, Interval_Offset, Align_Intervals, Restart_Notification_Recipients, Location
Analog Input	Yes	Yes	COV_Increment, Description, Event_Enable, Reliability, High_Limit, Low_Limit, Deadband, Limit_Enable, Time_Delay, Notification_Class, Notify_Type, Acked_Transitions, Event_Time_Stamps, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config	Present_Value, COV_Increment, Object_Name, Units, Description, Event_Enable, Out_Of_Service, High_Limit, Low_Limit, Deadband, Limit_Enable, Time_Delay, Notification_Class, Notify_Type, Acked_Transitions, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config
Analog Output	Yes	Yes	COV_Increment, Description, Event_Enable, Reliability, High_Limit, Low_Limit, Deadband, Limit_Enable, Time_Delay, Notification_Class, Notify_Type, Acked_Transitions, Event_Time_Stamps, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config	Present_Value, Relinquish_Default, COV_Increment, Object_Name, Description, Event_Enable, Out_Of_Service, High_Limit, Low_Limit, Deadband, Limit_Enable, Time_Delay, Notification_Class, Notify_Type, Acked_Transitions, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config
Analog Value	Yes	Yes	Priority_Array, Relinquish_Default, COV_Increment, Description, Event_Enable, Reliability, High_Limit, Low_Limit, Deadband, Limit_Enable, Time_Delay, Notification_Class, Notify_Type, Acked_Transitions, Event_Time_Stamps, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config	Present_Value, Relinquish_Default, COV_Increment, Object_Name, Description, Event_Enable, Out_Of_Service, Units, High_Limit, Low_Limit, Deadband, Limit_Enable, Time_Delay, Notification_Class, Notify_Type, Acked_Transitions, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config
Binary Input	Yes	Yes	Description, Event_Enable, Reliability, Inactive_Text, Active_Text, Elapsed_Active_Time, Change_Of_State_Count, Change_Of_State_Time, Time_Of_State_Count_Reset, Time_Of_Active_Time_Reset, Alarm_Value, Time_Delay, Notification_Class, Notify_Type, Acked_Transitions, Event_Time_Stamps, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config	Object_Name, Description, Event_Enable, Out_Of_Service, Inactive_Text, Active_Text, Alarm_Value, Polarity, Time_Delay, Notification_Class, Notify_Type, Acked_Transitions, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config
Binary Output	Yes	Yes	Minimum_Off_Time, Minimum_On_Time, Description, Reliability, Event_Enable, Inactive_Text, Active_Text, Time_Delay, Elapsed_Active_Time, Change_Of_State_Count, Change_Of_State_Time, Time_Of_State_Count_Reset, Time_Of_Active_Time_Reset, Notification_Class, Feedback_Value, Acked_Transitions, Notify_Type, Event_Time_Stamps, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config	Present_Value, Relinquish_Default, Minimum_Off_Time, Minimum_On_Time, Object_Name, Description, Event_Enable, Out_Of_Service, Inactive_Text, Active_Text, Elapsed_Active_Time, Time_Delay, Polarity, Feedback_Value, Notification_Class, Notify_Type, Acked_Transitions, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config
Binary Value	Yes	Yes	Priority_Array, Relinquish_Default, Minimum_Off_Time, Minimum_On_Time, Description, Event_Enable, Reliability, Inactive_Text, Active_Text, Elapsed_Active_Time, Change_Of_State_Count, Change_Of_State_Time, Time_Of_State_Count_Reset, Time_Of_Active_Time_Reset, Alarm_Value, Time_Delay, Notification_Class, Notify_Type, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config	Present_Value, Relinquish_Default, Minimum_Off_Time, Minimum_On_Time, Object_Name, Description, Event_Enable, Out_Of_Service, Inactive_Text, Active_Text, Elapsed_Active_Time, Alarm_Value, Time_Delay, Notification_Class, Acked_Transitions, Notify_Type, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config

Object Type	Dynamic Creation	Dynamic Deletion	Optional Properties Supported	Write Properties
Multi-State Output	Yes	Yes	Description, Reliability, Event_Enable, State_Text, Time_Delay, Notification_Class, Feedback_Value, Acked_Transitions, Notify_Type, Event_Time_Stamps, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config	Present_Value, Relinquish_Default, Object_Name, Description, Event_Enable, Out_Of_Service, State_Text, Time_Delay, Notification_Class, Feedback_Value, Acked_Transitions, Notify_Type, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config
Multi-State Value	Yes	Yes	Priority_Array, Relinquish_Default, Description, Event_Enable, Reliability, State_Text, Time_Delay, Notification_Class, Alarm_Values, Fault_Values, Acked_Transitions, Notify_Type, Event_Time_Stamps, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config	Present_Value, Relinquish_Default, Object_Name, Description, Event_Enable, Out_Of_Service, State_Text, Number_Of_States, Time_Delay, Notification_Class, Alarm_Values, Fault_Values, Acked_Transitions, Notify_Type, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config
Program	Yes	Yes	Description, Reliability	Object_Name, Description, Out_Of_Service, Program_Change
Loop	Yes	Yes	Proportional_Constant, Integral_Constant, Derivative_Constant, COV_Increment, Reliability, Bias, Description, Proportional_Constant_Units, Integral_Constant_Units, Derivative_Constant_Units, Time_Delay, Notification_Class, Error_Limit, Deadband, Event_Enable, Acked_Transitions, Notify_Type, Event_Time_Stamps, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config	Present_Value, Proportional_Constant, Integral_Constant, Derivative_Constant, COV_Increment, Object_Name, Out_Of_Service, Output_Units, Controlled_Variable_Reference, Setpoint, Setpoint_Reference, Action, Bias, Description, Manipulated_Variable_Reference, Priority_For_Writing, Proportional_Constant_Units, Integral_Constant_Units, Derivative_Constant_Units, Time_Delay, Notification_Class, Error_Limit, Deadband, Event_Enable, Acked_Transitions, Notify_Type, Event_Time_Stamps, Time_Delay_Normal, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config
File	No	No	Record_Count	File_Size, Record_Count
Notification Class	Yes	Yes	Description	Priority, Ack_Required, Recipient_List, Object_name, Description
Schedule	Yes	Yes	Weekly_Schedule, Exception_Schedule, Description	Present_Value, Priority_For_Writing, Object_Name, Weekly_Schedule, Out_Of_Service, Effective_Period, Exception_Schedule, Schedule_Default, Description, List_Of_Object_Property_References
Trend Log	Yes	Yes	Log_Device_Object_Property, Records_Since_Notification, Notification_Threshold, Last_Notify_Record, Stop_Time, Client_COV_Increment, Event_Enable, Reliability, Log_Interval, Trigger, Start_Time, Notification_Class, Acked_Transitions, Notify_Type, Event_Time_Stamps, Description, Interval_Offset, Align_Intervals, COV_Resubscription_Interval, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config	Buffer_Size, Log_Device_Object_Property, Notification_Threshold, Last_Notify_Record, Object_Name, Stop_Time, Client_COV_Increment, Stop_When_Full, Enable, Event_Enable, Logging_Type, Log_Interval, Trigger, Start_Time, Notification_Class, Acked_Transitions, Notify_Type, Description, Interval_Offset, Align_Intervals, COV_Resubscription_Interval, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config
Trend Log Multiple	Yes	Yes	Records_Since_Notification, Notification_Threshold, Last_Notify_Record, Event_Enable, Reliability, Start_Time, Trigger, Stop_Time, Notification_Class, Acked_Transitions, Notify_Type, Event_Time_Stamps, Description, Interval_Offset, Align_Intervals, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config	Buffer_Size, Log_Device_Object_Property, Notification_Threshold, Last_Notify_Record, Enable, Event_Enable, Start_Time, Log_Interval, Trigger, Stop_Time, Stop_When_Full, Notification_Class, Acked_Transitions, Notify_Type, Object_Name, Description, Interval_Offset, Align_Intervals, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config
Event Enrollment	Yes	Yes	Description, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config	Object_Property_Reference, Event_Parameters, Object_Name, Event_Enable, Notify_Type, Event_Type, Notification_Class, Acked_Transitions, Description, Event_Algorithm_Inhibit, Event_Algorithm_Inhibit_Ref, Event_Detection_Enable, Event_Message_Text_Config
Calendar	Yes	Yes	Description	Present_Value, Object_Name, Description, Date_List
Global Group	Yes	Yes	Description	Object_Name, Description, Group_Members, Out_Of_Service