

# BACnet CONFORMANCE CERTIFICATE



**No. BTL-31499**

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.20. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.3 and the BTL Testing Policies, see Test Report number TC51459 of Protocol Test Lab.

Product name (B-BC,B-BBMD,B-RTR,B-GW)
<b>Saia PCD</b>
<b>Model(s) PCD3.M6893</b>
Firmware version
<b>1.3.5.0</b>
Vendor
<b>Saia-Burgess Controls AG</b>
<b>Route Jo-Siffert 4</b>
<b>1762 Givisiez, Switzerland</b>

This certificate is valid until **31-Mar-2031**.

**02-Mar-2026**

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', written over a horizontal line.

Dipl.-Ing. G. Weinmann  
Head of Certification Body