

BACnet CONFORMANCE CERTIFICATE



No. BTL-30611-1

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.13. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 15.1 and the BTL Testing Policies, see Test Report number TC50916 of SoftDEL.

Product name (B-ASC)
Pressurized Environment Monitor
Model(s) PEM
Software version
1.2.0
Vendor
Setra Systems, Inc.
159 Swanson Road
Boxborough, MA 01719, USA

This certificate is valid until **31-Mar-2024**.

28-Sep-2020

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann
Head of Certification Body