

BACnet CONFORMANCE CERTIFICATE



No. BTL-31646

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.23. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 26.0 and the BTL Testing Policies, see Test Report number TC51449 of Protocol Test Lab.

Product name (B-BC,B-RTR,B-GW,B-BBMD)
IoT/Smart Building/Network Controller
Model(s) KXM-IP0080, KXM-16P, KXM-16P-D, KXM-20P, KXM-28P
Firmware version
2.0.18
Vendor
Shenzhen MEK Intellisys Pte Ltd. Unit 6, 6th Floor, Kechuang Building, Science and Technology Innovation Park, Houtingquan, Shajing Baoan District, Shenzhen, China

This certificate is valid until **31-Mar-2032**.

18-Sep-2026

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body